

A REVIEW OF CANADIAN TYPICAL YEAR WEATHER FILES FOR RESIDENTIAL ENERGY SIMULATION

By

Yu Ying Wang

B.Sc. In Environmental Sciences, University of Waterloo, 2016

A thesis

Presented to Ryerson University

In partial fulfillment of the

Requirements for the degree of

Masters of Applied Science

In the Program of

Building Science

Toronto, Ontario, Canada, 2020

AUTHORS DECLARATION FOR ELECTRONIC SUBMISSION OF A THESIS

I hereby declare that I am the sole author of this thesis. This is a true copy of the thesis, including any required final revisions, as accepted by my examiners.

I authorize Ryerson University to lend this thesis to other institutions or individuals for the purpose of scholarly research

I further authorize Ryerson University to reproduce this thesis by photocopying or by other means, in total or in part, at the request of other institutions or individuals for the purpose of scholarly research.

I understand that my thesis may be made electronically available to the public.

A REVIEW OF CANADIAN TYPICAL YEAR WEATHER FILES FOR RESIDENTIAL ENERGY SIMULATION

Masters of Applied Science 2020, Yu Ying Wang

Building Science Program, Department of Architectural Science, Ryerson University

The present study identifies changes in energy simulation of residential buildings in Toronto when three distinct weather simulation methodologies are used. The first is the Typical Year Canadian Weather File for Energy Calculations, the second is the actual meteorological data from the years of 1998 to 2018, and the last is an updated Canadian Weather File for Energy Calculations. The modelled buildings include a single-family home, high rise multi-unit residential building, and low rise multi-unit residential building. Missing meteorological data from the years 2015 to 2018 were collected from Environment Canada Historical Database and National Solar Radiation Database from the National Research Council Laboratory. The results show between a range of 12% monthly variance in energy consumption for low rise buildings, a range of 15% monthly variance in high rise buildings, and a range of 11% variance in single family homes. Annual variances range 2% in total energy variances. The single-family home is verified to an actual home. These results suggest that the monthly values when in a typical year simulation are not indicative of long term actual climate. In addition, this research analyzes the differences in selected months of the Canadian Weather File for Energy Calculations when the historical dataset used to generate the file is changed. Based on the gradual increase in CDD and decrease in HDD, simulations using an updated CWC represent a climate condition with less heating demand and more cooling demand.

ACKNOWLEDGEMENTS

I would like to thank Dr. Zaiyi Liao for being my supervisor and supporting this work. I would also like to thank Environment Canada, specifically Robert Morris, for his guidance in regards to the weather simulation files and providing the resources for that to be possible. To my friends, family and colleagues for their support – thank you.

TABLE OF CONTENTS

1.0	INTRODUCTION	1
2.0	LITERATURE REVIEW	4
2.1	Overview of Canadian Typical Year Weather File Creation	4
2.2	Overview on Weighting Factor Scenarios	7
2.3	Climate Factors in DOE2.3 Modeling Software	9
2.4	Cold Weather Climate Change Impacts	10
2.5	Background of Solar Data	11
2.6	North American Solar Radiation Models	12
2.6.1	SUNY.....	12
2.6.2	MAC3.....	13
2.6.3	NREL	13
2.7	Existing Work in Actual Meteorological Year (AMY) Files.....	14
2.8	Design Day Weather Files.....	19
2.9	Toronto Future Weather Files.....	19
3.0	RESEARCH DESIGN	21
3.1	Research Purpose.....	21
3.2	Research Questions.....	22
4.0	METHODOLOGY	23

4.1	AMY 1998 to 2018	23
4.2	Energy Model Selection of Parameters	27
4.2.1	City of Toronto Zero Emission Building Framework	28
4.2.2	Toronto Green Standard	28
4.2.3	Energy Star Ontario Version 12.8/2017	29
4.2.4	High Rise and Low Rise MURB	31
4.2.5	Single Family House Verification	35
4.3	Batch Simulation for Weather Files in eQUEST	39
4.4	NREL Climate Data Comparison	40
5.0	COMPARING MULTI-YEAR TO TYPICAL-YEAR BASED SIMULATIONS	44
5.1	Cumulative distribution functions for 2014 CWEC and CWEEDS	45
5.2	Low Rise MURB	51
5.2.1	Electricity	52
5.2.2	Natural Gas	56
5.3	High Rise MURB	57
5.3.1	Electricity	59
5.3.2	Natural Gas	60
5.4	Detached House	60
5.4.1	Model Verification	60

5.4.2	Electricity.....	69
5.4.3	Natural Gas	71
5.5	Energy Star Detached House.....	73
5.5.1	Electricity.....	75
5.5.2	Natural Gas	76
5.5.3	Comparison to Non-Energy Star Home	77
6.0	CREATED CWEC COMPARISONS	79
6.1	Toronto Low Rise MURB	82
6.2	Toronto High Rise MURB.....	84
6.3	Single Family Home	87
6.4	Alternative CWEC Years	91
7.0	FUTURE WORK AND CONCLUSIONS	98
7.1	Future Work	98
7.2	Conclusions.....	99
8.0	APPENDIX A – MODEL PARAMETERS.....	101
9.0	APPENDIX B – eQUEST REPORTS	107
10.0	REFERENCES	130

LIST OF TABLES

Table 1 – Weightings for FS statistics for CWEC	7
Table 2 - TMY1/TMY2 Weighting Factors	7
Table 3 – CWEC with Adjusted Weighting Factors	8
Table 4 - Total Annual Energy Consumption Comparison	15
Table 5 - Comparison of SAMSON Simulation Outputs	15
Table 6 – AMY versus typical year weather file energy simulation.....	16
Table 7 – AMY versus typical year weather file energy simulation.....	17
Table 8 – AMY versus typical year weather file energy simulation.....	18
Table 9 - CWEEDS formatted data positions and available data equivalents	24
Table 10 – Present Weather Data Positions Recorded.....	26
Table 11 – Toronto Green Standard Requirements	29
Table 12 – Energy Star Compliant Prescriptive Path	30
Table 13 – Modeled Building Types.....	31
Table 14 – Single Family Home Model Inputs	36
Table 15 – Calibration criteria for model verification [48]	37
Table 16 – 1998 to 2014 SUNY to NREL Review	41
Table 17 – Mean of DBT (°C) of 2014 CWEC and CWEEDS	50
Table 18 – 2014 CWEC and Σ 1998 – 2018	51
Table 19 – 2014 CWEC and Σ 1998 - 2014.....	52
Table 20 – September Electricity Load Comparisons	53
Table 21 – Toronto September Records of HDD and CDD at 18°C [55]	54

Table 22 – Monthly Electricity Deviations from CWEC from 1998 to 2018	55
Table 23 – 2014 CWEC and Σ 1998 – 2018	58
Table 24 – 2014 CWEC and Σ 1998 - 2014.....	58
Table 25 – Electricity Load Comparisons	59
Table 26 – Natural Gas Load Comparisons	60
Table 27 – Single Family Home Verification Electricity Consumption (kWh)	60
Table 28 – Single Family Home CDD and kWh Correlation per Day	64
Table 29 - Single Family Home Verification Natural Gas Consumption (m ³).....	65
Table 30 – Single Family Home CDD and kWh Correlation per Day	66
Table 31 – Model Matched to Domestic Hot Water Usage.....	68
Table 32 - 2014 CWEC and Σ 1998 - 2014.....	69
Table 33 - 2014 CWEC and Σ 1998 - 2018.....	70
Table 34 – Annual Electricity Load Comparisons.....	70
Table 35 – Comparison of Annual Means.....	71
Table 36 - 2014 CWEC and Σ 1998 – 2018.....	74
Table 37 - 2014 CWEC and Σ 1998 - 2014.....	74
Table 38 – Annual Electricity Load Comparisons.....	75
Table 39 – Annual Natural Gas Load Comparisons.....	76
Table 40 – Electricity and Natural Gas Comparison with Energy Star and Non-Energy Measures	78
Table 41 – Changed Typical Meteorological Months of 1998 to 2018 CWEC	80
Table 42 – Dry Bulb Temperature (°C) Distribution Comparison	82

Table 43 - Electricity and Gas Consumption Variation	82
Table 44 – Load Changes between CWEC 2014 to CWEC 2018.	83
Table 45 – CWEC Space Heating Natural Gas Consumption	85
Table 46 – CWEC Space Cooling Electricity Consumption	86
Table 47 – Single Family Home Created CWEC Comparisons.....	87
Table 48 – Comparisons between CWEC from CWEEDS datasets.....	91
Table 49 – Monthly and Annual HDD, CDD and Total Irradiance kJ/m ²	92
Table 50 – Single Family Home CWEC Analysis	96

LIST OF FIGURES

Figure 1 – Toronto 1938 – 2019 CDD (18°C).....	1
Figure 2 - Toronto 1938 - 2019 HDD (18°C).....	1
Figure 3 – Simulation Structure	25
Figure 4 – Monthly GHI (kJ/m ²)	42
Figure 5 – Monthly DNI (kJ/m ²)	42
Figure 6 – Hourly DHI (kJ/m ²)	43
Figure 7 – January CWEC 2014 to CWEEDS distribution.....	45
Figure 8 – February CWEC 2014 to CWEEDS distribution	45
Figure 9 - March CWEC 2014 to CWEEDS distribution	46
Figure 10 – April CWEC 2014 to CWEEDS distribution	46
Figure 11 - May CWEC 2014 to CWEEDS distribution.....	46
Figure 12 - June CWEC 2014 to CWEEDS distribution	47
Figure 13 – July CWEC 2014 to CWEEDS distribution	47
Figure 14 - August CWEC 2014 to CWEEDS distribution	47
Figure 15 - September CWEC 2014 to CWEEDS distribution.....	48
Figure 16 – October CWEC 2014 to CWEEDS distribution.....	48
Figure 17 - November CWEC 2014 to CWEEDS distribution.....	48
Figure 18 – December CWEC 2014 to CWEEDS distribution	49
Figure 19 – Single Family Home Electricity Normalized to Modelled Comparison	61
Figure 20 – Single Family Home Electricity Simulated to Bill Comparison	62
Figure 21 – CDD/Day and Electricity Usage/Day Comparison	63

Figure 22 –Natural Gas Polynomial Line of Fit.....	65
Figure 23 - HDD/Day and m ³ /Day Comparison.....	67
Figure 24 – Running Average of Heating Degree Days (1940 to 2018)	72
Figure 25 – Running Average of CDD/HDD Ratio for Toronto	76
Figure 26 – Distribution comparison between hourly DBT of 2014 CWEC and CWEEDS	81
Figure 27 – Distribution comparison between hourly DBT of 2018 CWEC and CWEEDS	81
Figure 28 – CWEC MURB Space Heating (m ³).....	84
Figure 29 – CWEC MURB Space Cooling (kWh)	85
Figure 30 – Monthly Cooling Electricity (kWh)	89
Figure 31 – Monthly Heating Natural Gas (m ³)	89
Figure 32 – Monthly Cooling (kWh)	90
Figure 33 – Monthly Heating (m ³)	90
Figure 34 – Annual CWEC Solar Irradiance Trends	94
Figure 35 – Annual CWEC HDD Trends	95
Figure 36 – Annual CWEC CDD Trends.....	95

1.0 INTRODUCTION

Global temperatures in North America have been on the increase since roughly 1900 [1].

Toronto, Canada has observed several temperature anomalies within the last 80 years. For example, cooling demand in 2016 surpassed the previous mean annual cooling demand by 40% [2]. As seen in figures 1 and 2, the trend of cooling degree days (CDD) and heating degree days (HDD) in Toronto are sloping upwards for CDD and upward for HDD. The changing climate presents a need to better estimate ongoing climate conditions for energy simulation.




Figure 1 – Toronto 1938 – 2019 CDD (18°C)




Figure 2 - Toronto 1938 - 2019 HDD (18°C)

Toronto is rapidly growing and adding an estimated 24,400 more people to its permanent population every year in 2014 [3]. A report from KPMG released in August of 2019 shows that the city itself has gained more than 300,000 new residents, constructed 220,000 residential units and currently pending city approval for 167,000 residential units [4]. The city keeps a database of development applications for future projects which are publically accessible [5]. For a period of 180 days, there were 50 applications for developments in just the downtown core to East York. In North York, Etobicoke and Scarborough, there were 95 applications for developments within those same 150 days. Of those developments approximately a third were multi-unit residential housing units and a quarter were single family or low rise housing applications [5]. For each new development, an energy model is required in the schematic design phase of a building. Projects in the City of Toronto are required to submit an energy modelling report as a part of the site plan application. An updated energy modelling report is also required as a part of the building permit application. The conclusions of the models for all new developments must be in line with the Toronto Green Standard. This standard has set energy and greenhouse gas targets for each new development. The compliance to these targets are reflected in the energy model. Typically, an energy model is created several years prior to the building being operational. Model verification is not required by the City of Toronto, and modelled simulation values are not commonly compared to actual metered energy after the building has operated for a year. Therefore, the modelled simulation should be as accurate as possible to predict future energy usage. In order for the model to simulate energy appropriately for future conditions, the climate data used in the model needs to be representative of historical weather patterns. The work done in this study will investigate the current accuracy in

assumed climate conditions in Toronto within an energy model. The most current climate data readily available for energy modellers to use is data between the years of 1998 to 2014. The data available is 5 years behind the last full calendar year. This work presents an updated review of the current climate condition in Toronto, focusing on the years 2014 to 2018. In addition, one typical year weather file is created from the range of years 1998 to 2014. This methodology of created an artificial year is done so the most representative months are selected of the historical data. In Canada, this artificial year is the Canadian Weather Year for Energy Calculations. This study analyzes how the Canadian Weather Year for Energy Calculations file is created and its representativeness of the 17 years it estimates.

2.0 LITERATURE REVIEW

In order to gain an understanding of the existing research and relevant topics of study surrounding climate files in energy simulation, a literature review is presented. The beginning of the review summarizes how the properties of Canadian Weather Year for Energy Calculations file and how it is processed by modelling engines. This includes a background of the solar data included in the simulation files and the solar radiation models which have previously been used in typical year weather files. In order to understand whether the files are representative of the broader years they are intended to estimate, a comparison of typical year simulations to individual actual year simulations is presented. Following that, a broader review of differing weather files for purposes relevant to energy simulations are presented.

2.1 Overview of Canadian Typical Year Weather File Creation

A Canadian Typical Year Weather File (CWEC) is a typical year weather file created to estimate historical actual meteorological data. As a requirement for most energy modelling software, the file has 8760 hours of weather data selected from different years within a larger dataset. The purpose of this typical year approach is to reduce the computations efforts of simulation and simplify the results generated, in addition to standardizing all weather inputs across the industry so results from different modellers can be compared [6]. The CWEC was built upon the methodology of a Typical Meteorological Year. The Typical Meteorological Year (TMY) method was created in the SANDIA National Laboratories in the United States and is a widely adopted methodology of creating an artificial year for energy simulation. A typical year (TY) consists of 12 typical meteorological months selected from a database of years. They are intended to be

used for computer based building simulation, as the weather is a primary external factor to building's internal loads. The Canadian Weather Year for Energy Calculation (CWEC) is the Canadian created typical year file and is generated in WYEC2 format by Watsun Simulation Laboratory [7]. The CWEC is selected from the Canadian Weather Energy and Engineering Dataset (CWEEDS), which includes data from 492 locations in Canada [8]. The most recent 2016 CWEC file was created using data from 1998 to 2014 in the CWEEDS dataset, which includes a combination of observed, satellite modeled, interpolated, and estimated data. For the duration of this report, this file will be referred to as 2014 CWEC based on the last year of data the file includes. The climate factors included in the CWEEDS are; extraterrestrial irradiance (kJ/m^2), global horizontal irradiance (kJ/m^2), direct normal irradiance (kJ/m^2), diffuse horizontal irradiance (kJ/m^2), global horizontal illuminate (100 lux), direct normal illuminance (100 lux), diffuse horizontal illuminance (100 lux), zenith luminance (100 Cd/m^2), minutes of sunshine (0-60 minutes), ceiling height (10m), sky condition, visibility (100m), present weather, station pressure (10 Pa), dry bulb temperature (0.1 C), dew point temperature (0.1 C), wind direction (0-359 degrees), wind speed (0.1 m/s), total sky cover (0-10 in tenths), opaque sky cover (0-10 in tenths) and snow cover (snow or no snow). A large portion of global horizontal irradiance (GHI) and direct normal irradiance (DNI) data are not available through actual measured data. Therefore, modeled satellite data is used for stations where data is unavailable. Perez's State University of New York (SUNY) solar satellite model is the particular modelled data used, and is advantageous over the previous solar model as monitoring cloud and sky conditions would no longer be required to estimate irradiance [8].

The following steps are taken to create a CWeC file from the CWeEDS dataset [7]:

- Daily values are compiled from the CWeEDS files of the elements used to select the typical months i.e. GHI, temperature, dew point and wind speed
- Finkelstein-Schafer (FS) statistics, with assigned relative weights on solar, dry bulb (t), dew point (Td), and wind speed (WS) values are used to identify the five candidate months for each month of the year whose cumulative probability distributions (CDF) of daily values used with the weighting scheme most closely match the CDF of all of those months from the entire long-term data set. Months with any missing data in the weighted fields are blocked.
- The five candidate months are ranked with respect to the closeness of the mean and median of each month to that of the long-term data set.
- Persistence statistics concerning the frequency and run lengths of consecutive days above and below fixed percentiles are compiled.
- Persistence criteria are used to exclude the month with the longest run, the month with most runs, and any months with zero runs from the candidate months from the third step above. The highest ranked month not excluded by the persistence criteria is selected as the typical month. It sometimes happens (fewer than 10% of the locations) that all of the 5 highest ranked months for a particular month are excluded by the persistence criteria and a TMY software does not generate a CWeC file – in these cases the script processing the files reruns the TMY software with a prescribed list of months to use including the accepted months and the highest ranked month which was previously excluded.

- The 12 selected months are joined to make a nominal year and the 6 hours on each side of the month boundaries are smoothed by interpolation to remove step changes in the hourly data.

2.2 Overview of Weighting Factor Scenarios

As mentioned in the second step to creating the CWEC, weighting factors are necessary to express the relative importance of each climate index on building performance [9]. The following weights are used in generating CWEC files to reflect the assumed influence the various elements have on building energy usage [7].

Table 1 – Weightings for FS statistics for CWEC

Index	Max dry bulb	Min dry bulb	Mean dry bulb	Max dew point	Min dew point	Mean dew point	Max wind speed	Mean wind speed	Global radiation
CWEC	5%	5%	30%	2.5%	2.5%	5%	5%	5%	40%

A comparison of index weightings in alternative weather methodologies is found in table 2 [10];

Table 2 - TMY1/TMY2 Weighting Factors

Index	Max dry bulb	Min dry bulb	Mean dry bulb	Max dew point	Min dew point	Mean dew point	Max wind speed	Mean wind speed	Global radiation	Direct radiation
TMY1	4.17%	4.17%	8.33%	4.17%	4.17%	8.33%	8.33%	8.33%	50%	n/a
TMY2/TMY3	5%	5%	10%	5%	5%	10%	5%	5%	25%	25%

Several researchers have looked into the impacts of changing the above weighting factors and performed sensitivity analysis when changing the percentages of each index. From as early as 1994 in the User's Manual for TMY2, weightings between solar and other elements were not found to be particularly sensitive [10]. Table 3 summarizes the studies that have calculated a typical year weather file with adjusted weighting factors. The conclusions from the reviewed research show that changes to the dry bulb, wet bulb and humidity weighting factors presented little effect on the typical year weather file created. However, changes to the solar radiation weighting factors were significant and impacted model simulation up to 20% in energy usage [12].

Table 3 – CWeC with Adjusted Weighting Factors

Ref	Intent	Findings
[11]	Reviews selection of weighting parameters on test reference year for Subang, Malaysia. 6 variations of the indexes for dry bulb, global solar radiation, relative humidity and wind speed are performed, ranging from being equally divided among all four to a slight additional impact on each index over the others.	It was found that equally weighted index's gave the best correlation between the selected TRY'S for individual variables. Replacing relative humidity by calculating moisture content did not significantly affect the selection.

Table 3 – CWeC with Adjusted Weighting Factors

Ref	Intent	Findings
[12]	Investigates the generation of typical and example weather years for Hong Kong. Based on one variation of 11/24 weighting applied to solar radiation and wind speed, the building simulation was reevaluated to review the energy performance of a hybrid solar-wind energy system	For a hybrid solar-wind energy generation system, a difference of 20% in simulation result was found when compared with original TMY weighting factors.
[13]	The intent of the parameter selection of ¼ global solar radiation, ¼ direct solar radiation, and ¼ dry bulb temperature is that a large portion of the building cooling is dependent on the solar radiation data.	12 TMMs are generated into a TMY file and are within the long term average daily data for the 10 year dataset.

2.3 Climate Factors in DOE2.3 Modeling Software

How is the climate file used in modeling software? One common energy modeling engine used is the United States Department of Energy (DOE) created engine. DOE2.3 is the latest modeling software used in eQUEST, an energy simulation tool. Not all climate conditions represented in the CWeC and CWeEDS are considered by DOE2.3. Only the following variables are used by the DOE2.3 modeling engine [14]; Dry bulb Temperature (°C), Wet bulb Temperature (°C), Atmospheric Pressure (Pa), Wind Speed (knots), Wind Direction (compass points 0-15, with 0 being north, 1 NNE,

etc.), Cloud Amount (0 - 10, with 0 clear and 10 totally cloudy), Cloud Type (0, 1, or 2) 0 is cirrus or cirrostratus, the least opaque; 1 is stratus or stratus fractus, the most opaque; and 2 is all other cloud types, of medium opacity, Humidity Ratio (pounds of water per pound of dry air), Density of Air (lb/m^3), Specific Enthalpy (BTU/lb), Rain Flag (0 means it is not raining; 1 means it is), Snow Flag (0 means it is not snowing; 1 means it is), Total Horizontal Solar Radiation ($\text{BTU}/\text{hr}\cdot\text{m}^2$), and Direct Normal Solar Radiation ($\text{BTU}/\text{hr}\cdot\text{m}^2$). In comparison to CWEEDS and CWEC data, several parameters have been eliminated and are not considered.

2.4 Cold Weather Climate Change Impacts

In Toronto, heating degree days significantly outweigh cooling degree days. The city is currently classified as ASHRAE climate zone 6A and is considered a cold weather climate. As climate change impacts the ratio of heating degree days to cooling degree days in a year, climate files in cold climates need to reflect this change to appropriately model heating and cooling demand. Jentsch et al. identifies that TMY weather files for building energy performance are derived from historical weather data not updated to the last several years, and discrepancies exist between TMY files and current weather trends [26]. In Canada, the same issues arise from the use of CWEC. With the now widely accepted effects of climate change, the net annual impact on annual energy usage for buildings in cold climates is positive, with a reduction of 10% or more to annual energy usage [21]. Cold climates are able to take advantage of the tempered climate and model more conservative heating demand in winter months.

2.5 Background of Solar Data

Solar data is important to the accuracy of a weather file. Solar radiation data is weighed as 40% of the weighting parameter for the selected typical meteorological month. Therefore, a representative climate file requires accurate predictions for solar data. Historically, solar data was kept through human monitored sites. However, this method is flawed as it is reflective of the observer's biases and potential inconsistencies in data based on the gaps in periods observed. [27]. Alternatively, measuring solar radiation data can be done using thermal sensing pyranometer and pyrhemometers. A pyranometer measures the global horizontal illuminance (GHI), while the pyrhemometer measures the direct normal irradiance (DNI) [28]. DHI is known as diffuse sky radiation and is measured as the amount of radiation at the earth's surface from light scattered by the atmosphere. It is measured on a horizontal surface with radiation coming from all points in the sky. There would be almost no DHI in the absence of the atmosphere [29]. DNI is the amount of solar radiation received per unit area by a surface that is always held perpendicular to the sun rays that come in a straight line from the direction of the sun and its current position in the sky. Typically, DNI can be maximized to the amount of irradiance annually received by a surface by keeping it perpendicular to incoming radiation. DNI is equal to the extraterrestrial irradiance above the atmosphere exempting the atmospheric losses due to absorption and scattering. This irradiance is also dependent on the distance to the sun. This value is typically represented in W/m^2 [30]. GHI is the total irradiance from the sun on a horizontal surface on Earth. It is the sum of direct irradiance after accounting for the solar zenith angle of the sun and diffuse horizontal irradiance [31]. Solar radiation incident outside the earth's atmosphere is called extraterrestrial radiation. This is not of significance to the

impact of an energy model on Earth. Solar luminance data is unavailable in most satellite derived data sets, and is not an impact on the selection of the CWEC, nor a weather element impacting the DOE 2.1 simulation engine. Therefore, default values from EnergyPlus can be used to estimate global horizontal illuminance, direct normal illuminance, diffuse horizontal illuminance, and zenith luminance.

2.6 North American Solar Radiation Models

The primary challenge in collecting accurate data for new climate files in Canada is the availability of solar radiation data. Environment Canada uses SUNY satellite radiation data version 3 [32], which uses visible and infrared satellite data compared with ground measured solar data to produce an hourly dataset to a resolution of a 10km² grid.

2.6.1 SUNY

The hourly dataset on a 10km² grid for Canada south of 58 degree latitude north based on Perez's State University of New York (SUNY) GOES satellite-based solar model was produced first in 2009 using SUNY Version 1 model, which uses visible channels satellite imagery. This data covered seven years (2002-2008) and may be found on the FTP website of NRCan at <ftp://ftp.nrcan.gc.ca/energy/SOLAR>.

SUNY V1 model is the model used to generate the post-1998 US National Solar Resource Data Base (NSRDB). Recently this direct normal irradiance (DNI) and global horizontal irradiance (GHI) satellite-derived solar resource Canadian data was updated for the period of eleven (11) years covering 1998 to 2008 using improved SUNY model Version 3 beta. This latest SUNY model makes use of both visible and infra-red channels imagery and is meant to correct for the

winter bias that is experienced when using Version 1 of the SUNY model in particular during snow conditions and persistent cloud cover, so-called “Eugene syndrome” Currently and as part of an on-going project, three additional years of solar data covering the period from 2009 to 2011 are generated using the latest SUNY V3 model to obtain a total of fourteen years of hourly solar resource data for south Canada. Version 1 of the SUNY model has been extensively assessed mainly with ground measured data from US locations and terrains [33]

2.6.2 MAC3

Previously, the McMaster (MAC) 3 was used for the CWEEDS dataset to generate estimates for DNI, GHI, and DHI. This model uses cloud cover and aerosol transmittance to estimate radiation. The modeled solar radiation in these files was compared to solar radiation calculated by the SUNY version 3 model. Reda Djabbar et al. had found that overall SUNY version 3 estimates were comparably more accurate than MAC3 estimates [32]. Though GHI stayed relatedly similar with an MBE of only -1%, the difference in estimating the DNI between the two models is around 7%, where SUNY provides a lower value for DNI than MAC3 [32]. This overestimation is in line with Gueymard who represented an overestimation of approximately 9% for DHI of the MAC3 model.

2.6.3 NREL

As SUNY weather data is not publically available, NREL’S National Solar Radiation Database (NSRDB) is used to source radiation estimates. The current version (v2.0.0) was developed using the Physical Solar Model (PSM), which uses satellite imagery to derive DHI, GHI and DNI for all years between 1998 and 2018. The satellite imagery covers roughly 0.038 degrees of latitude and 0.038 degrees of longitude for a 4km resolution in data [34]. The irradiance data have been

validated in a previous study and have recorded confidence between 5% to 10% of GHI and DNI [10].

2.7 Existing Work in Actual Meteorological Year (AMY) Files

With an understanding of how CWEC and TMY files are created and used, a review is done on how representative they are of the actual meteorological years they are calculated based on. Several researchers have investigated the variances in energy output from simulation using various weather climate files. In particular, studies have compared energy simulation using a typical year weather file to actual meteorological years. As this study is focusing on the Canadian scope and CWEC dataset, research which includes CWEC data in WYEC2 format is primarily reviewed. In 1998, Crawley ran simulations in DOE-2.1 simulation engine for a prototype office building using WYEC2, TMY2, CWEC and CTZ2 data for a variety of locations in North America. The simulations were compared with Solar and Meteorological Surface Observational Network (SAMSON) dataset [17], which contains 30 years of hourly weather and solar data for years 1961 – 1990. Crawley found some discrepancies between the total annual energy consumption when simulated using CWEC weather file and the average of the SAMSON actual meteorological years.

Table 4 - Total Annual Energy Consumption Comparison

Weather File Type	Total Annual Energy Consumption, ekWh/m²-yr
SAMSON Average	2.216
TMY	2.3%
TMY2	-0.4%
WYEC	1.6%
WYEC2 (TMY)	--
WYEC2 (CWEC)	1.4%

In Minneapolis, Minnesota (ASHRAE Climate Zone 6A), Crawley found a 1.4% difference in the total annual energy consumption between CWEC weather and SAMSON 1961-1990 AMY average weather [18][19]. In Denver, Colorado (ASHRAE climate zone 5B), he found a -1.2% variance in the same parameters. In New York, (ASHRAE climate zone 5A), he found a 3.2% variance in the same parameters.

Table 5 - Comparison of SAMSON Simulation Outputs

	Annual Consumption, (% of SAMSON average)	Electric Demand, (% of SAMSON average)	Cooling Load, (% of SAMSON average)	Heating Load, (% of SAMSON average)
TMY	2.3%	1.4%	20.9%	-0.7%
TMY2	-0.4%	-2.2%	-1.5%	-7.3%
WYEC	1.6%	-1.0%	2.4%	-5.1%
WYEC2 (TMY)	--	--	--	--
WYEC2 (CWEC)	1.4%	-1.8%	-0.8%	-5.8%

This research has not been repeated for the years following 1990 for CWEC. There is a correlation in energy simulation outputs to the effects of climate change in cold climates

[20][21], and discrepancies have been found between current weather trends and other types of typical year weather files. Some of these discrepancies are summarized in table 6;

Table 6 – AMY versus typical year weather file energy simulation

Ref	Research Intent	Finding(s)	Year
[6]	Compare energy simulation results from TMY with those from individual years and their long term means.	Monthly load and energy consumption profiles followed the TMY quite closely. Minimal variation in mean bias error and root mean square errors.	2007
[22]	Reviews how several sets of international typical meteorological data sets compare to the actual period of record that they represent.	The climatic response of the building would be better served by a range of building climatic data, with variance in temperature, humidity, solar radiation and wind conditions. Recommendations include higher weights on dry bulb and solar radiation than in traditional TMY methods using seasonal averages to select the months to comprise XMY's.	2019

Table 7 – AMY versus typical year weather file energy simulation

Ref	Research Intent	Finding(s)	Year
[18]	This paper presents results from the DO2.1 hourly energy simulation program for a prototype office building as influenced by locally measured weather data for multiple years and several weather data sets for eight US locations.	A TMY2 or WYEC2 can be used to represent a weather period, however the files may need to be adjusted to match the long term average statistics more closely to the mean of the full data set. A possible approach is to create a typical weather file that has three years: typical (average), cold/cloudy, and hot/sunny.	2018
[23]	This portion of this paper compares effects on outdoor air temperature and relative humidity to a model using TMY3 versus AMY. Models are generated for a number of building types and their comparisons are documented.	For within a range of building types, electricity usage intensity deviates when using AMY weather files and TMY3 weather from 0.3% to 2.4%. Natural gas usage intensity deviates when using AMY weather files and TMY3 weather from 3.9% to 40.9%.	2019

Table 8 – AMY versus typical year weather file energy simulation

Ref	Research Intent	Finding(s)	Year
[24]	This paper compares the performance of TMY, TRY, WYEC, DRY and SMY weather files in energy simulation. It discusses the selection process of each of their parameters and how they differ between different modelling software.	This paper finds that the major limitation in the accuracy of the weather data is access to long term weather data which includes hourly values of solar radiation and meteorological elements for hourly periods.	2012
[25]	The AMY data from Meteoronorm is compared against a variety of typical meteorological years for three different climate zones within Norway. This comparison is done to consider the deviation for these three climate zones as it pertains to an energy labelling scheme.	Deviations range between 2.1 to 8.9% in total annual energy consumption between Meteoronorm data and IWECC. This deviation is significant enough to recommend that the labelling will need to consider separate climate zones in its labelling criteria.	2018

2.8 Design Day Weather Files

It should be made clear that CWEC data is not to be used for calculating heating and cooling peak loads, sizing HVAC equipment or sizing any renewable system. As typical year data is representative of a range of years and average conditions of those years, peak weather data would not be appropriately estimated. Design day (DD) weather files are used to estimate peak weather conditions. For Toronto, design day conditions are outlined in both ASHRAE and the Ontario Building Code reference. A design day file includes a period of peak conditions for both heating and cooling to maintain the design indoor conditions. Design day files are a statistical representation of annual season for warming days (0.4%, 1% and 2%) and cooling days (99.6% and 99%). As these files are directly impacting the sizing of mechanical equipment, updated design day files based on current weather data is central to impacting better designed buildings for future conditions [15]. The DOE2.3 software within eQUEST does allow the modeller to define a design heating and cooling design day. When design day is not specified, the software will calculate the peak heating and cooling loads based on the weather file [16].

2.9 Toronto Future Weather Files

One type of weather file relevant to energy simulation is future weather files. Future weather files anticipate future climate conditions instead of historical averages. There are two primary methodologies for forecasting climate in the future. The first methodology is well documented as “morphing” and calculates based on a historic means [35]. It heavily relies on statistical analysis to forecast future weather trends. There are arguments that this methodology is not reliable for predicting weather events that have not previously occurred like extreme climate events. The second methodology is the Weather Research and Forecasting (WRF) model [36].

This model takes into account the classic morphing method but also considers the dynamic, non-linear events between all climate parameters and their predicted futures. The WRF model is able to better predict extreme weather events and trends which have not historically happened [37]. In Toronto, a specific 2040 to 2049 weather file has been created based on a commissioned report from the City of Toronto by SENES Consultants Limited [38]. This was built using the WRF methodology and focuses on the climate around the Toronto Pearson International Airport within a 1x1km resolution around the Greater Toronto Area. The results of the study show an increased number of CDD and an increase in occurrences of extreme heat periods. In addition, the study shows an increase in freeze-thaw events, storms and tornados and major rain events. One major climate finding was that Toronto will shift to ASHRAE climate zone 4 by 2040 [38], as a result of increased cooling demand and decreased heating demand from climate change.

Through the literature review, there is a gap in knowledge in exactly how the current Toronto CWEC weather file compares to the climate years it estimates. In addition, no literature reviewed had created an updated climate file to the latest calendar year to review the impacts on energy usage. The work of this research will be to narrow this gap in knowledge for future energy simulations.

3.0 RESEARCH DESIGN

The objective of this study is to compare the representativeness of the 2014 CWEC file with long term actual meteorological year data. While new data is being collected daily and being made available to the general public, this research asks whether creating custom weather files with up to date weather years creates meaningful variations to energy simulations results and review correlations to the historical weather datasets.

3.1 Research Purpose

The intent behind this research is twofold; identify discrepancies between artificial TMY climate and historical long-term climate and review changes to the CWEC with added years to the CWEEDS. This research seeks to understand how representative the CWEC is for the climate variations in the last 17 to 21 years. In regards to the practical estimation of operational costs, this research may inform the design and operation of a future building and provide a better range of estimates for annual and monthly operational costs [39]. As the climate changes, operating costs for the buildings will change. Many optimization processes for buildings do not review the year or year impacts of weather changes. In order to consider the range in annual averages, this research would contribute to that estimation.

3.2 Research Questions

The following research questions are to be answered in performing this work:

- 1) What are the energy consumption impacts of simulating individual years of 1998 to 2014, compared to the typical year weather file last released, CWeC 2016?
 - a. How does this differ between a high rise residential building, low rise residential building, and a single family home?
- 2) When 2015 to 2018 is added to the dataset, does the final output of the CWeC change?
 - a. Are those changes impactful on the energy performance of the energy model?
 - b. If those incremental changes are significant, should an AMY weather file be created every year to support better estimated simulated energy?

4.0 METHODOLOGY

This research requires that building energy simulations are run against each type of weather file. Figure 3 reviews the variations of simulations performed. A total of 96 simulations were done. In order to run the model with the long term climate data, 21 individual AMY weather files were created from the CWEEDS and historical data. As the CWEEDS data was updated with data from subsequent years, 8 new CWEC files were generated.

4.1 AMY 1998 to 2018

In order to compile a CWEC with additional years of data for 2015 to 2018, as well as splitting out the individual AMY years, the Toronto International Airport CWEEDS file was used as it's a central location within the GTA. It was necessary to compile the data in the same data formatting as the CWEEDS file. As such, the formatting of the weather data was compiled within the data positions show on Table 9. For values available through Environment Canada, hourly data was exported in the historic weather database and populated into the CWEEDS format accordingly. Of the data available, several sections were reformatted for unit consistency with the CWEEDS. For values indicating "not included" in the CWEEDS, the values were unavailable. The values do not impact the performance of a building energy model as the DOE modeling engine does not consider those values against building parameters. CWEEDS are originally formatted as WY3 files and require the following specific formatting;

- Hours are recorded on a 01 to 24 scale, as opposed to 00 to 23 which Environment Canada generates.
- The unit for irradiance data is kJ/m^2 , as opposed to the format of NREL data in W/m^2 .

- Present weather is derived from weather flags reported by Environment Canada, with flags matched to the formatting of the CWEEDS.
- Dry bulb temperature and dew point temperature are formatted as 0.1C to avoid decimals.

Table 9 - CWEEDS formatted data positions and available data equivalents

Data Position	Flag Position	Weather Elements in CWEEDS	Equivalent Site Weather Data Source Location
001-007	--	ECCC station identifier	Environment Canada
008-008	--	File source code (always 'B')	B
009-018	--	Year, Month, Day, Hour (YYYYMMDDHH)	Environment Canada
019-022	--	Extraterrestrial irradiance, kJ/m ²	NREL PSM Data
023-026	027-028	Global horizontal irradiance, kJ/m ²	NREL PSM Data
029-032	033-034	Direct normal irradiance, kJ/m ²	NREL PSM Data
035-038	039-040	Diffuse horizontal irradiance, kJ/m ²	NREL PSM Data
041-044	45	Global horizontal illuminance, 100 lux	default EnergyPlus
046-049	50	Direct normal illuminance, 100 lux	default EnergyPlus
051-054	55	Diffuse horizontal illuminance, 100 lux	default EnergyPlus
056-059	60	Zenith luminance, 100 Cd/m ²	default EnergyPlus
061-062	63	Minutes of sunshine, 0-60 minutes	Not included
064-067	68	Ceiling height, 10 m	Not included
069-072	73	Sky condition	Not included
074-077	78	Visibility, 100 m	Environment Canada
079-086	87	Present Weather	Environment Canada Derived
088-092	93	Station pressure, 10 Pa	Environment Canada
094-097	98	Dry bulb temperature, 0.1 C	Environment Canada
099-102	103	Dew point temperature, 0.1 C	Environment Canada
104-106	107	Wind direction, 0-359 degrees	Not included
108-111	112	Wind speed, 0.1 m/s	Environment Canada
113-114	115	Total sky cover, 0-10 in tenths	Not included
116-117	118	Opaque sky cover, 0-10 in tenths	Not included
119-119	120	Snow cover (0 = no snow cover, 1 = snow cover)	Environment Canada Derived




Figure 3 – Simulation Structure

Table 10 defines the methodology in which the present weather data was derived from Environment Canada downloaded historical data into CWEED formatted codes. The present weather is used to define the weather at each hour and includes levels of different categories combined into an 8 digit code.

Table 10 – Present Weather Data Positions Recorded

Data Position: 79	Data Position: 80	Data Position: 81	Data Position: 82
0 = None	0 = None	0 = None	0 = None
1 = Thunderstorm	1 = Rain	1 = Drizzle	1 = Light Snow
2 = Heavy Thunderstorm	2 = Moderate Rain	2 = Moderate Drizzle	2 = Moderate snow
3 = Tornado	3 = Heavy Rain	3 = Heavy Drizzle	3 = Heavy Snow
	4 = Rain Showers	4 = Light Freezing Drizzle	4 = Light snow pellets
	5 = Moderate Rain Showers	5 = Moderate Freezing Drizzle	5 = Moderate snow pellets
	6 = Heavy Rain Showers	6 = Heavy Freezing Drizzle	6 = Heavy snow pellets
	7 = Light Freezing Rain	7 = Light Freezing Drizzle	7 = Light ice crystals
	8 = Moderate or Heavy Freezing Rain	8 = Moderate or Heavy Freezing Drizzle	8 = Moderate ice crystal
Data Position: 83	Data Position: 84	Data Position: 85	Data Position: 86
0 = None	0 = None	0 = None	0 = None
1 = Light snow showers	1 = Light ice pellets	1 = Fog	1 = Smoke
2 = Moderate snow showers	2 = Moderate ice pellets	2 = Ice Fog	2 = Haze
3 = Heavy snow showers	3 = Heavy ice pellets	3 = Blowing Dust	3 = Smoke and Haze
4 = Light snow grains	4 = Light hail	4 = Sand	4 = Dust
5 = Moderate snow grains	5 = Moderate hail		5 = Blowing Snow
6 = Heavy snow grains	6 = Heavy hail		
	7 = Light ice pellet showers		
	8 = Moderate or heavy ice pellet showers		

4.2 Energy Model Selection of Parameters

In order to consider the impacts of updated weather simulation and extension of years on various types of buildings, three building types were chosen to represent the standard archetype of buildings in their respective categories. An archetype building is an average building of that particular stock, and a representation of typical geometry, construction characteristics and operation of a building [40]. Based on the changes in the local new development zoning, site plan and permit requirements, two different sets of models are developed for each location. The modeled buildings follow the general trend of new buildings in Toronto. Work has already been done to represent the building stock of Toronto with archetype buildings from local municipalities, developers and consultants. The basis of the archetypes rely on three standards/best practice frameworks;

- 1) City of Toronto Zero Emissions Buildings Framework Report [3]
- 2) National Energy Code for Buildings 2017 (NECB) [41]
- 3) ASHRAE 62.1 and ASHRAE 62.2 [42]

The City of Toronto Zero Emissions Building Framework was used to match prescriptive inputs to the archetype model. The plan defines reasonable parameters to follow which is reviewed in further detail in the following sections. In Toronto, baseline performance for new developments is Toronto Green Standard Tier 1 Version 3.0 [43]. This level of compliance is required to be shown at the site plan application phase. In terms of building permit, the model must abide by the baseline Ontario Building Code Supplementary Standard 10, which

references the standard ASHRAE 90.1 [44]. The buildings modelled comply with both these requirements.

4.2.1 City of Toronto Zero Emission Building Framework

Within the City of Toronto Zero Emissions Building Framework, a range of acceptable parameters are available for envelope performance and mechanical equipment performance, while baseline values for occupancy, scheduling, plug loads, lighting, pumps, fans and infiltration are set. For parameters where a range of performance was indicated, the value which would contribute to the most amount of energy savings was selected. For example, in the range of RSI 1.76 to RSI 3.52 wall insulation, RSI 3.52 was modeled. The reason for this is that the Toronto Green Standard is scheduled to update every 4 years and being pushed in the direction of near zero emissions level of building performance by 2030. To anticipate a shift to better envelopes, the highest of the range provided has been used.

4.2.2 Toronto Green Standard

The Toronto Green Standard is a requirement for new developments within the City of Toronto to meet specific sustainability and energy targets. The standard itself is based on a tiered system, ranging between Tier 1 to Tier 4. With each tier, the requirements become more stringent. Compliance with Tier 1 is mandatory however all subsequent tiers are voluntary. Under the current version of the standard (Version 3.0), the energy targets have been summarized in table 11. Both EUI and TEDI are represented in kWh/m² and GHG is represented in kg/m²[45].

Table 11 – Toronto Green Standard Requirements

Requirement	TGS v3 Tier 1			TGS v3 Tier 2			TGS v3 Tier 3		
	EUI kWh/m ²	TEDI kWh/m ²	GHG kg/m ²	EUI kWh/m ²	TEDI kWh/m ²	GHG kg/m ²	EUI kWh/m ²	TEDI kWh/m ²	GHG kg/m ²
Low Rise MURB	165	65	20	130	40	15	100	25	10
High Rise MURB	170	70	20	135	50	15	100	30	10

4.2.3 Energy Star Ontario Version 12.8/2017

A model was built to represent a building that is compliant with Energy Star Ontario Version 12.8/2017. Natural Resources Canada had released the latest of Energy Star for New Home Standard version 12.8 and Version 17.0 for Ontario [46]. All enrollments in the Energy Star program in Ontario apply to this version. The standard poses a stringent energy target for new homes and is largely based on building approximately 20% better than the current building code/reference house [46]. One popular compliance path offered is the prescriptive path, which does not require a full energy model. A Builder Option Package (BOP) plus options are selected, and the building satisfies Energy Star requirements by being compliant with the BOP package. For the purpose of this research, a BOP option has been selected which focuses on airtightness requirements as the Housing Assistance Council has noted that this is one of the most affordable methods of achieving compliance to the standard [47]. In terms of general upgrades, Energy Star homes are a premium from the typical home. All elements of the building envelope are upgraded from the baseline SB-12 home, additional air sealing is required to be done and tested, higher efficiency heating and cooling equipment are installed

and a whole home ventilation system is also installed. The model was built to the standards listed in the table 12.

Table 12 – Energy Star Compliant Prescriptive Path

Component	Prescriptive Path	BOP
Ceiling with Attic Space	RSI 5.46 m ² ·K/W	Core
Exposed Floor	RSI 5.46 m ² ·K/W	Core
Walls Above Grade	Eff RSI 3.79 m ² ·K/W	0.7
Basement Walls	Eff RSI 3.77 m ² ·K/W	Core
Below Grade Slab Entire Surface	RSI 1.76 m ² ·K/W	OBC
Edge of Below Grade Slab	RSI 1.76 m ² ·K/W	OBC
Windows and Sliding Glass Doors	1.4 W/m ² K	OBC
Space Heating Equipment (AFUE)	96%	Core
HRV (SRE)	75%	0.2
Domestic Hot Water Heater (EF)	0.8 condensing tank	0.2
Air Leakage ACH (Air changes per hour) / Normalized leakage rate (NLR)	0.35 L/s/m ²	0.7
Air Conditioning	13 SEER	Core
Electrical Credits (kWh)	Energy Star HRV (>=1.2 cfm/W)	110
Electrical Credits (kWh)	75% CFL/LED	295
Required BOP		1.9
Required Electrical Credits		405

4.2.4 High Rise and Low Rise MURB

Table 13 summarizes all the inputs for the high rise and low rise MURB archetype buildings used to run the simulations.

Table 13 – Modeled Building Types

Characteristics	High Rise MURB	Low Rise MURB
Building Area	22,658 m ² plus 10,568 m ² parking	5,366 m ² plus 2,352 m ² parking
Operating Hours	NECB Schedule G occupancy, lighting and plug loads for suites. NECB Schedule B occupancy, lighting and plug loads for fitness. Corridor and parking lighting always on.	NECB Schedule G occupancy, lighting and plug loads for suites. NECB Schedule B occupancy, lighting and plug loads for fitness. Corridor and parking lighting always on.
Occupancy	100 m ² /person Corridor 27.9 m ² /person Suites 5 m ² /person Fitness, Pool	100 m ² /person Corridor 27.9 m ² /person Suites
Plug & Process Loads	5 W/ m ² Suites 1 W/ m ² Fitness, Pool 4.5 kW elevator load 30 kW Suite exhaust fans, 2 h/day 41.4 kW Parking exhaust fans, 4 h/day	5 W/ m ² Suites 1 W/ m ² Fitness 1.0 kW elevator load 4 kW Suite exhaust fans, 2 h/day 9.2 kW Parking exhaust fans, 4 h/day

Table 13 – Modeled Building Types

Characteristics	High Rise MURB	Low Rise MURB
Outdoor Air	Per ASHRAE 62.1-2010 Suites: 2.5 L/s/person and 0.3 L/s/ m ² Ventilation effectiveness 0.8 Corridors: 30 cfm/suites Pool: 2.4 L/s/ m ² Fitness: 10 L/s/person and 0.3 L/s/ m ²	Per ASHRAE 62.1-2010 Suites: 2.5 L/s/person and 0.3 L/s/ m ² Ventilation effectiveness 0.8 Corridors: 30 cfm/suites Pool: 2.4 L/s/ m ² Fitness: 10 L/s/person and 0.3 L/s/ m ²
Infiltration	0.25 L/s/ m ² Exterior Area, Code DOE-2 Coefficients	0.25 L/s/ m ² Exterior Area, Code DOE-2 Coefficients
Wall R-Value	Eff. RSI 2.27 m ² ·K/W	Eff. RSI 3.52 m ² ·K/W
Roof R-Value	RSI 6.06 m ² ·K/W	RSI 5.28 m ² ·K/W
Window U-Value	Overall U-1.88 W/m ² K	Overall U-1.88 W/m ² K
Window SHGC	0.38	0.35
WWR	40%	30%

Table 13 – Modeled Building Types

Characteristics	High Rise MURB	Low Rise MURB
Lighting	5 W/m ² Suites 7.1 W/m ² Corridors 7.8 W/m ² Fitness/Pool 2 W/m ² Parking 2 kW Exterior Lights	5 W/m ² Suites 7.1 W/m ² Corridors 7.8 W/m ² Fitness 2 W/m ² Parking 2 kW Exterior Lights
HVAC System	Suites: Gas boiler and chiller as heating and cooling plant to fan coils and ERVS Corridors: MUA with Hydronic baseboards Fitness and Pool: Unitary Systems, pool with cool/reheat humidity control	Suites: Gas boiler and chiller as heating and cooling plant to fan coils and ERVs Corridors: MUA with Hydronic baseboards Fitness: Hydronic Unitary System
Supply and Ventilation Air	Constant ventilation air supplied directly to zones through DOAS. Fan coil fans cycle to meet heating and cooling loads.	Constant ventilation air supplied directly to zones through DOAS. Fan coil fans cycle to meet heating and cooling loads.
Heat Recovery	Options: 65% to 85% Suite ERV efficiency Electric Preheat Coil to -5°C	Options: None to 85% Suite ERV efficiency Electric Preheat Coil to -5°C

Table 13 – Modeled Building Types

Characteristics	High Rise MURB	Low Rise MURB
Fans	Options: Standard: 1.0 W/cfm ERVs, Corridor MUA 1.2 W/cfm Fitness, Pool Unitary 0.5 W/cfm Fan Coils, continuous ECM: 0.5 W/cfm ERVs, Corridor MUA 0.75 W/cfm Fitness, Pool Unitary 0.3 W/cfm Fan Coils, cycling	Options: Standard: 1.0 W/cfm ERVs, Corridor MUA 1.2 W/cfm Fitness 0.5 W/cfm Fan Coils, continuous or cycling ECM: 0.5 W/cfm ERVs, Corridor MUA 0.2 W/cfm Fan Coils, cycling
Cooling	Water-cooled Screw Chiller, COP5.2	Water-cooled Screw Chiller, COP 5.2
Heating	Mid-Efficiency Boiler, 90% eff	Condensing Boiler, 95% eff.
Pumps	22 m head, variable speed HW, DHW, CHW Secondary, and CndW 22 m head, constant speed CHW Primary	22 m head, variable speed HW, DHW, CHW Secondary, and domestic HW 22 m head, constant speed CHW Primary
DHW	500 W/person Suites Same as Heating Plant, with top up boiler for supply temperature	500 W/person Suites Same as Heating Plant, with top up boiler for supply temperature

4.2.5 Single Family House Verification

The following procedures were followed when collecting data for the energy model of the single family house;

1) Pre-visit work

- a. Review of 2 year's energy consumption historical data
- b. Gather information on the buildings footprint, coordinates and types of mechanical systems in place

2) Building data collection

- a. Measured the building geometry and measured all windows from within to determine final window wall ratio
- b. Measured all interior zones, identified demising walls
- c. Confirmed orientation of the building
- d. Located unconditioned and conditioned spaces
- e. Located all doors and door types
- f. Installed WattsUP meter of all major appliances to collect data for one week
- g. Setpoint confirmation with HOBO sensors in the control zone
- h. Data collection of all secondary appliances
- i. Data collection of the furnace and air conditioner
- j. Conducted a lighting audit
- k. Confirmed water fixture flow rates
- l. Conducted as-built blower door test
- m. Occupancy pattern verification based on a smart thermostat

- n. Thermal couple to confirm thermal resistance in above-grade walls, windows and sliding glass doors.
 - o. Conducted an interview of building occupants to confirm schedule.
- 3) Analysis of building energy use
- a. Review at energy consumption trends
 - b. Creating custom scheduling for lighting, plug loads, occupancy, heating, and cooling.

Table 14 summarizes the model inputs for eQUEST.

Table 14 – Single Family Home Model Inputs

Component	Input	Collection Method
West Window Wall Ratio	11%	Measured
South Window Wall Ratio	16%	Measured
East Window Wall Ratio	11%	Measured
North Window Wall Ratio	4%	Measured
Total Window Wall Ratio	10.5%	Measured
Total Floor Area (m ²)	394.26	Measured
Occupants (m ² /person)	197.19	Calculated
Ceiling with Attic Space	RSI 3.7	SB-10
Exposed Floor	RSI 3.7	SB-10
Walls Above Grade	RSI 3.17	Measured
Basement Walls	RSI 1.76	SB-10
Lighting Power Density (W/m ²)	0.436	Measured
Equipment Power Density (W/m ²)	1.336	Measured
Slab on Grade Floors	RSI 3.52	SB-10
Windows and Sliding Glass Doors	U-1.42	Measured
SHGC	0.40	SB-10
Heating Electric Input Ratio (power/power)	1.088	Manufacturer Documentation
Domestic Hot Water Heater (EF)	0.95	Manufacturer Documentation
Hot Water Usage (lpm)	0.2343	Calculated
Air Leakage ACH (Air changes per hour) @50 Pa	4.74	Measured
Cooling Electric Input Ratio (power/power)	0.199	Manufacturer Documentation

The verification process of building inputs was performed to ensure that the model is as close as possible to accurate. The model was validated against the 2018 AMY year and 2018 utility data and was run with 1998 to 2018 AMY, 2014 CWeC and 2018 CWeC weather files. This process is a type of building measurement and verification; which is a methodology used to establish a measure of accuracy in the original model and recognize any issues with the operation of the building [48]. There are several calibration criteria that are used to validate the model. Table 15 organizes the three main criteria together and the various thresholds for normalized mean biased error (NMBE) and coefficient of variation of the root mean square error (CV(RMSE)) under ASHRAE guideline 14 [49], [50], Federal Energy Management Program (FEMP) [51], [52] and International Performance Measurement and Verification Protocol (IPMVP) [53].

Table 15 – Calibration criteria for model verification [48]

Data/Calibration	Index	FEMP	ASHRAE	IPMVP
Monthly %	NMBE	±5%	±5%	±20%
	CV(RMSE)	15%	15%	-
Monthly	R ²	-	>0.75	>0.75

NMBE, CVRMSE and R^2 are defined as the following equations:

$$NMBE = 100 \frac{\sum (y_i - \hat{y}_i)^2}{(n-p) \times \bar{y}} \quad (1)$$

$$CV(RMSE) = 100 \frac{\sqrt{\frac{\sum (y_i - \hat{y}_i)^2}{(n-p)}}}{\bar{y}} \quad (2)$$

$$R^2 = \left[1 - \frac{\sum_{i=1}^n (y_i - \hat{y}_i)^2}{\sum_{i=1}^n (\bar{y} - \hat{y}_i)^2} \right] \times 100 \quad (3)$$

Where:

y_i = measured data point

\hat{y}_i = simulated data point

\bar{y} = mean of measured data points

n = number of data points per period

p = number of parametric outputs

NMBE is a normalized calculation of the MBE will is able to scale the MBE by the average of all measured values. This produces the total error of the predicted and verified set of data. Based on ASHRAE guidelines, the total error is derived from subtracting measured values from the simulated, in order to show the over or underestimation of the predicted values. Similar to NMBE, the CV(RMSE) is also normalized to the mean of the measured values.

R^2 is referenced in ASHRAE and IPMVP, and compares the model to the regression line of the measured data. Though this is referenced, there are a number of issues with R^2 which may impact the verification of the model. The first is that with an increase in the number of predictors and observations in the model, R^2 will have a slightly better fit as that number increases, suggesting the best fit would be for as many data points as possible. It's possible that with additional predictors, the model is overfit and can produce misleadingly high R^2 . However, for the purpose of this research, the criteria will be matched with what ASHRAE and IPMVP have recommended.

4.3 Batch Simulation for Weather Files in eQUEST

There is functionality to run multiple simulations at a time with unique weather files for each run. This is helpful to minimize computing time and reduce the effort needed for multiple year energy simulations. In eQUEST, batch simulations can be run. Through batch processing, an array of measures can be specified and run through the detailed mode of eQUEST. The methodology was adapted from a presentation given by Kevin Madison in a 2012 IBPSA Seattle event [54]. There are modifications of all three basic eQUEST and DOE 2.2 properties within the same instruction set; Wizard properties, DOE2.2 keywords and global parameters. Within the batch file, the specific weather files are pulled in to run through the Wizard properties. No other parameters were changed in this process.

4.4 NREL Climate Data Comparison

NREL'S National Solar Radiation Database (NSRDB) is used to source radiation estimates and has been previously verified to accurately estimate solar radiation data with confidence up to 95%. However, the previous estimates used were SUNY and in order to determine the relationship with SUNY V3, an analysis is done to confirm consistency between SUNY data and NREL data between the years of 1998 to 2014 for Toronto. The Vancouver International Airport is also included as a data point to understand changes in a warmer climate. Data extracted from SUNY in the CWEEDS was converted to W/m^2 , and compare for all three irradiance types; DHI, DNI and GHI. The data reviewed is summarized in table 16 and identifies confidence in the data at an annual, monthly, daily and hourly resolution. The values are within a similar range of RMSE and MSE as the analysis previously performed by the NREL for various American locations, and similar to the assessment done for original SUNY verification with ground observations. The results of the NREL analysis found that when compared to ground based measurements, the mean bias error of the NSRDB database was within 5% for GHI and less than within 10% for DNI. When compared with RMSE, the hourly averages were as significant as 20% for GHI and 40% for DNI. Variability in RMSE and MSE decreased as the resolution in time was reduced, which is consistent with the results in table 16. Approximately a 5% variability was found on average across all time spans. As sufficient evidence is available that SUNY and NREL data are closely matched, this research will continue to use NREL data to estimate the solar irradiance data needed for all newly created weather files. The average SUNY values are from a study comparing SUNY data averages over 18 Canadian stations and measured ground data for GHI and 3 stations for DNI [32]. Annual data was not provided.

Table 16 – 1998 to 2014 SUNY to NREL Review

Station	Time Avg.	No. Obs.	GHI – RMSE (%)	GHI – MBE (%)	DNI – RMSE (%)	DNI – MBE (%)	DHI – RMSE (%)	DHI – MBE (%)
SUNY v3 Avg.	Hourly	149016	27.8	1.9	67.2	14.3	-	-
	Daily	6209	15	1.9	52.1	14.3	-	-
	Monthly	204	6.7	2.1	25.8	14.6	-	-
NREL	Hourly	149016	19.35	2.72	21.73	-0.35	17.24	4.60
TOR to	Daily	6209	10.49	2.72	9.01	-0.34	6.34	4.61
SUNY	Monthly	204	7.65	2.71	2.94	-0.34	3.25	4.71
	Annually	17	4.86	2.71	1.52	-0.34	2.64	4.71
NREL	Hourly	149016	18.35	1.14	26.23	7.03	16.23	3.95
VAN to	Daily	6209	9.26	1.14	15.21	7.21	10.43	3.90
SUNY	Monthly	204	6.36	1.24	8.62	6.55	6.76	3.91
	Annually	17	2.65	1.43	7.33	7.01	3.58	3.92

Table 16 identifies that there are similar correlations between SUNY data and NREL data. The first of these correlations is that as the timeline average of data increase from hourly to monthly, the errors diminish. The reason for that the radiation data is averaged over a larger timeframe and more likely to be a closer match when averaged. The second correlation is that the NREL data is within the range of RMSE and MBE of SUNY data. This means that NREL estimates do not display any additional errors beyond SUNY estimates. Figures 4 to 6 show the monthly average solar radiation in Toronto. Based on the charts, it is clear that NREL data is within a similar pattern and range as previous SUNY data.




Figure 4 – Monthly GHI (kJ/m^2)




Figure 5 – Monthly DNI (kJ/m^2)




Figure 6 – Hourly DHI (kJ/m²)

The modelling and calculation methodology outlined has specified the procedure and techniques used to calculate the research results. The data collected through this methodology is further analyzed in a meaningful way to answer the research questions.

5.0 COMPARING MULTI-YEAR TO TYPICAL-YEAR BASED SIMULATIONS

The first research question will be answered in this chapter. The question states; What are the energy consumption impacts of simulating individual years of 1998 to 2014, compared to the typical year weather file last released, CWEC 2016? How does this differ between a high rise residential building, low rise residential building, and a single family home? The only weather dependent loads in an energy model are heating, cooling, ventilation fans and domestic hot water. Of these loads, there are three major components affected by the weather file; dry bulb temperature, solar radiation and relative humidity. It impacts heat transfer through the envelope, solar gains through the windows and total latent loads. The intention behind this analysis is to determine whether Toronto's long term climate is represented in the CWEC 2014 weather file. If there are monthly discrepancies, how significant are those ranges? When calculating the percentage difference between both datasets, the % difference between both simulation results is compared to review underestimation or overestimation of the weather by CWEC. Formula 4 is used whenever % difference is calculated.

$$\% \text{ Difference} = \frac{E_{CWEC} - E_{AMY}}{(E_{CWEC} + E_{AMY})/2} \quad (4)$$

Where:

E_{CWEC} = CWEC data point

E_{AMY} = AMY data point

5.1 Cumulative distribution functions for 2014 CWEC and CWEEDS

In order to calculate whether the 2014 CWEC is correlated to the CWEEDS for dry bulb temperature, a review of the cumulative distribution of both datasets is done. The following graphs compare the distribution of occurrences in hourly dry bulb temperatures ($^{\circ}\text{C}$) of the CWEC with that of the entire dataset from 1998 to 2014. The blue curve represents the entire data set with over 11,500 occurrences, dependent on the month. The orange curve represents the cumulative CWEC occurrences. Data is grouped into months, where the x-axis is DBT in Celsius and the y-axis is distribution frequency.




Figure 7 – January CWEC 2014 to CWEEDS distribution




Figure 8 – February CWEC 2014 to CWEEDS distribution




Figure 9 - March CWEC 2014 to CWEEDS distribution




Figure 10 – April CWEC 2014 to CWEEDS distribution




Figure 11 - May CWEC 2014 to CWEEDS distribution




Figure 12 - June CWEC 2014 to CWEEDS distribution




Figure 13 – July CWEC 2014 to CWEEDS distribution




Figure 14 - August CWEC 2014 to CWEEDS distribution




Figure 15 - September CWEC 2014 to CWEEDS distribution




Figure 16 – October CWEC 2014 to CWEEDS distribution




Figure 17 - November CWEC 2014 to CWEEDS distribution




Figure 18 – December CWEC 2014 to CWEEDS distribution

The CWEC distribution is within the range of CWEEDS distribution, however does not encompass the full range in temperatures. For example, In December the distribution of temperatures is between -10°C to 7°C. In the CWEEDS dataset, December distribution of temperatures is between almost -25°C to 16°C. The CWEC dry bulb temperatures do not consider hotter or colder than average temperatures. In some months, there is deviation from the CWEED average dry bulb temperature. For example, in October there are fewer occurrences of temperatures between 0°C to 10°C and more occurrences of temperatures between 10°C to 20°C.

Table 17 – Mean of DBT (°C) of 2014 CWeC and CWeEDS

	1998 to 2014	2014 CWeC	Absolute Error	% of 1 σ
January	-4.5504	-6.0700	1.5197	22.5
February	-3.6736	-3.2764	0.3972	7.3
March	0.9358	1.2224	0.2867	4.5
April	7.5168	7.6985	0.1816	3.2
May	14.2655	14.5991	0.3335	6
June	19.4874	19.7526	0.2653	5.3
July	22.2611	22.2243	0.0368	0.8
August	21.3703	21.8793	0.5090	11.9
September	17.3792	17.1061	0.2731	5.4
October	10.3525	10.3399	0.0126	0.2
November	4.5404	3.7225	0.8179	16.3
December	-1.3292	-0.0409	1.2883	23.8
Mean Absolute Error			0.4935	

Absolute error between the means of dry bulb temperature is compared between the two datasets. The reason for comparing the errors is to understand the magnitude of the errors between the average dry bulb temperatures. The purpose of comparing these two sets is to identify differences in the overall mean of the dry bulb temperatures monthly, and whether that would be a potential area for error in the modelling results. It was found that the dry bulb temperature monthly mean has errors ranging from 0.0126 °C to 1.5197 °C. The three highest errors are in three consecutive months; November, December and January. In all cases, the absolute error was less than 23.8% of 1 standard deviation. In terms of correlation to the main dataset, the CWeC is a close fit to the mean based on dry bulb temperature. This suggests that the correlation fit to the CWeEDS dataset is sufficient in regards to dry bulb temperature in the summer months. However, deviation exists in the winter months. In order to review whether discrepancies are evident in the total model, the entirety of the 17 years is compared against the 2014 CWeC for each model built.

5.2 Low Rise MURB

For a low-rise multi-unit residential building, the simulation results shown in Table 18 and 19 compares the simulation results of the dataset of AMY 1998 to 2018 and AMY 1998 to 2014 compared to the original 2014 CWEC.

Table 18 – 2014 CWEC and Σ 1998 – 2018

	Electric Consumption (kWh)		Error %	Gas Consumption (m ³)		Error %
	Original CWEC x 21	Σ 1998 - 2018		Original CWEC x 21	Σ 1998 - 2018	
January	811566	813533	0%	221945	209742	6%
February	736518	738639	0%	179177	179020	0%
March	834095	834044	0%	153665	157541	-2%
April	831179	836407	-1%	105149	107403	-2%
May	954946	964797	-1%	68052	69603	-2%
June	1054550	1073022	-2%	53693	53006	1%
July	1204209	1216888	-1%	48944	48885	0%
August	1162514	1185095	-2%	44760	44767	0%
September	964595	1019863	-5%	46403	46337	0%
October	855571	876925	-2%	75488	78386	-4%
November	795446	801302	-1%	129468	122615	6%
December	812317	814107	0%	171950	182227	-6%
RMSE			19775			5267
MAPE			1.30			2.43
Total Error			-157115			839
Total	11017506	11174621		1299532	1298692	

Table 19 – 2014 CWEC and Σ 1998 - 2014

	Electric Consumption (kWh)		Error %	Gas Consumption (m ³)		Error %
	Original CWEC x 17	Σ 1998 - 2014		Original CWEC x 17	Σ 1998 - 2014	
January	656982	657462	0%	179670	170706	5%
February	596229	596512	0%	145048	144872	0%
March	675219	675231	0%	124395	126931	-2%
April	672859	676614	-1%	85121	85736	-1%
May	773051	773657	0%	55089	56507	-3%
June	853683	867943	-2%	43465	43017	1%
July	974836	979237	0%	39621	39703	0%
August	941083	951038	-1%	36234	36380	0%
September	780863	811278	-4%	37564	37856	-1%
October	692605	704925	-2%	61109	64097	-5%
November	643933	646739	0%	104807	99883	5%
December	657590	658356	0%	139198	148385	-6%
RMSE			80059			4154
MAPE			0.83			2.40
Total Error			10885			2752
Total	8918933	8998992	-1%	1051322	1054074	-1%

5.2.1 Electricity

Absolute error in electricity consumption ranges from 0% to -5% in all months. As referenced earlier, CDD is on the incline. In particular, September electricity consumption stands out as an outlier in 2014 CWEC simulations and AMY simulations. To compare the actual differences in the modeled load in September, a load comparison is shown on table 20.

Table 20 – September Electricity Load Comparisons

Electricity (kWh)	2014 CWEC x 17	Σ 1998 - 2014	-/+	Error %	2014 CWEC x21	Σ 1998 - 2018	-/+	Error %
Space Cool	170115	199769	-29654	-16%	210142	264428	-54287	-23%
Heat Reject.	65	81	-17	-23%	80	116	-37	-37%
Refrigeration	0	0	0		0	0	0	
Space Heat	0	0	0		0	0	0	
HP Supp.	0	0	0		0	0	0	
Hot Water	0	0	0		0	0	0	
Vent. Fans	118754	118779	-26	0%	146696	146575	121	0%
Pumps & Aux.	17610	18328	-718	-4%	21753	22819	-1065	-5%
Ext. Usage	0	0	0		0	0	0	
Misc. Equip.	349281	349281	0	0%	431465	431465	0	0%
Task Lights	0	0	0		0	0	0	
Area Lights	125039	125039	0	0%	154460	154460	0	0%
Total	780863	811278	-30415	-4%	964595	1019863	-55268	-6%

The space cooling load is the most significant change between the original CWEC and AMY. In each simulation, the underestimation of cooling load accounts for over 95% of the total difference in electrical load. The only loads affected are a direct result of the climate file change, as no other parameters in the model were adjusted. In order to review whether the cooling load discrepancy can be further explained by the range of CDD, table 21 presents the ranges in CDD for the period.

Table 21 – Toronto September Records of HDD and CDD at 18°C [55]

September	HDD			CDD		
	Record	CWEC	%	Record	CWEC	%
1998	1191	1291	8%	45	24	-61%
1999	1264	1291	2%	49	24	-68%
2000	1525	1291	-17%	36	24	-41%
2001	1137	1291	13%	38	24	-44%
2002	1378	1291	-7%	98	24	-121%
2003	1291	1291	0%	24	24	0%
2004	1279	1291	1%	43	24	-56%
2005	1297	1291	0%	60	24	-85%
2006	1252	1291	3%	14	24	53%
2007	1268	1291	2%	67	24	-95%
2008	1444	1291	-11%	27	24	-11%
2009	1336	1291	-3%	21	24	14%
2010	1401	1291	-8%	32	24	-27%
2011	1159	1291	11%	42	24	-54%
2012	1295	1291	0%	37	24	-42%
2013	1458	1291	-12%	29	24	-17%
2014	1333	1291	-3%	31	24	-27%
2015	1056	1291	20%	82	24	-109%
2016	1166	1291	10%	74	24	-102%
2017	1336	1291	-3%	80	24	-107%
2018	1389	1291	-7%	85	24	-112%
1998 to 2014	22306	21945	-2%	691	408	-51%
1998 to 2018	27252	27109	-1%	1010	504	-67%

In the 2014 CWEC, the month of September is represented by 2003. The month of September selected has the third lowest total CDDs of all years in the span. Therefore, all subsequent months are underestimated for an average of 51% up to 2014. This increases to 67% when years up to 2018 are considered. The cooling of the low rise building is modeled with an electric chiller, therefore the electrical space cooling load discrepancy between -16% for 17 years and -23% for 21 years can be explained by the low CDDs as there would be less need to operate the chiller. When the model is run with all the AMYs, table 22 summarizes all the generated outputs

for changes in electricity consumption. From 1998 to 2014, errors range from -2.05% to 3.29% when compared to the CWeC. When the additional 4 years are added, errors range between 2.31% to 5.62%.

Table 22 – Monthly Electricity Deviations from CWeC from 1998 to 2018

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
1998	0.06%	1.25%	2.33%	1.90%	7.85%	3.01%	-1.70%	3.23%	6.85%	2.68%	-0.08%	1.74%	2.46%
1999	0.21%	0.84%	1.03%	-0.35%	2.35%	5.02%	6.29%	-4.88%	4.92%	1.26%	0.64%	0.16%	1.57%
2000	0.22%	0.22%	1.18%	-1.12%	-0.05%	-3.32%	-7.44%	-2.11%	1.15%	2.91%	0.24%	-0.16%	-0.99%
2001	-0.27%	-0.60%	-1.63%	1.40%	-0.30%	2.79%	-4.12%	6.46%	2.77%	1.68%	1.63%	0.63%	0.93%
2002	0.42%	0.38%	-1.10%	1.73%	-5.18%	1.01%	8.34%	5.77%	14.46%	2.34%	-0.14%	-0.07%	2.70%
2003	-0.17%	-0.26%	-0.51%	0.38%	-8.01%	-3.12%	-3.91%	2.58%	0.44%	1.12%	-0.12%	0.25%	-1.05%
2004	-0.16%	0.05%	-1.77%	-1.07%	-4.01%	-5.82%	-6.39%	-7.57%	7.25%	0.60%	0.27%	-0.36%	-1.95%
2005	0.08%	0.09%	-1.22%	0.79%	-4.76%	13.45%	6.65%	4.65%	9.93%	4.08%	0.66%	-0.16%	3.29%
2006	0.49%	-0.42%	0.63%	1.70%	2.59%	3.64%	8.10%	2.11%	-3.04%	-0.33%	0.04%	0.13%	1.58%
2007	0.43%	0.11%	-0.51%	-0.48%	3.61%	6.80%	-2.49%	3.93%	7.68%	8.59%	0.09%	0.09%	2.42%
2008	-0.24%	-0.71%	-2.13%	3.90%	-6.92%	0.74%	-2.63%	-5.59%	1.17%	0.38%	0.25%	-0.34%	-1.21%
2009	-0.34%	-0.01%	-0.06%	0.40%	-3.32%	-6.05%	-10.6%	-0.25%	2.05%	-3.15%	1.24%	-0.15%	-2.04%
2010	-0.25%	-0.25%	2.25%	4.61%	7.28%	1.08%	7.54%	7.48%	0.19%	0.78%	0.85%	-0.44%	2.94%
2011	0.19%	0.23%	-1.00%	-2.03%	-2.09%	-0.26%	7.19%	1.15%	3.49%	3.22%	1.70%	0.73%	1.23%
2012	0.34%	0.60%	5.07%	-0.22%	6.02%	4.05%	5.12%	1.73%	0.60%	-0.72%	0.62%	0.24%	2.14%
2013	0.50%	-0.19%	-0.87%	-1.12%	6.06%	1.26%	3.65%	1.08%	2.23%	4.39%	0.22%	0.09%	1.59%
2014	-0.26%	-0.51%	-1.67%	-0.93%	0.31%	4.08%	-5.72%	-1.78%	4.04%	0.39%	-0.70%	-0.39%	-0.34%
2015	1.43%	0.37%	0.39%	1.84%	8.22%	-1.71%	2.03%	0.60%	14.98%	2.19%	3.61%	1.20%	2.96%
2016	0.99%	1.48%	0.19%	0.39%	5.72%	5.16%	6.95%	14.47%	13.05%	8.60%	3.95%	0.39%	5.62%
2017	0.57%	1.81%	-0.88%	3.44%	-2.95%	2.39%	-0.26%	-0.90%	13.71%	10.06%	1.12%	0.53%	2.31%
2018	0.86%	1.57%	0.14%	-1.95%	9.36%	2.56%	5.77%	8.64%	12.32%	1.32%	-0.63%	0.52%	3.80%

5.2.2 Natural Gas

There is no significant difference in total natural gas consumption over the year. Broken down into the separated loads, there are minor differences in consumption for both space heat and hot water.

Natural Gas (m³)	2014 CWECC x 17	Σ 1998 - 2014	-/+	%	2014 CWECC x21	Σ 1998 - 2018	-/+	%
Space Cool	0	0	0		0	0	0	
Heat Reject.	0	0	0		0	0	0	
Refrigeration	0	0	0		0	0	0	
Space Heat	506637	508938	-2301	-0.5%	625846	627247	-1401	-0.2%
HP Supp.	0	0	0		0	0	0	
Hot Water	544685	545136	-451	-0.1%	672847	672285	561	0.1%
Vent. Fans	0	0	0		0	0	0	
Pumps & Aux.	0	0	0		0	0	0	
Ext. Usage	0	0	0		0	0	0	
Misc. Equip.	0	0	0		0	0	0	
Task Lights	0	0	0		0	0	0	
Area Lights	0	0	0		0	0	0	
Total	1051322	1054074	-2752	-0.3%	1298693	1299532	-840	-0.1%

In the heating season, defined between the months of October to March, consumption differs from -5% to 6% when compared to the dataset of 1998 to 2014 and -6% to 6% when compared to the dataset of 1998 to 2018. There is up to a 0.3% difference in annual energy consumption between CWECC and AMY. Based on how minor this difference is, the CWECC has estimated the natural gas consumption appropriately during this period.

5.3 High Rise MURB

The high rise MURB is interesting as it has the highest ratio of window to wall area, with 40% window and 60% wall. This would emphasize any differences in the solar radiation data as the solar heat gain would be more significant for a building with more windows. In addition, the high rise MURB building is modelled with a typical boiler and chiller, heating and cooling plant. This requires additional pumps to push the hot and cold water to each individual suite and amenity fan coils. The fan powers on individual fan coils, air handling units, ERV fans, and the make-up unit air unit fan are all impacted by the changes in weather data. As high rise MURB projects are required to demonstrate compliance with Toronto Green Standard Tier 1, climate file accuracy is important as the City takes the energy model into consideration for energy planning policies. Tables 23 and 24 summarize the impacts on electricity and gas consumption of the 2014 CWEC and the respective dataset years. A breakdown of the individual loads is explained in the subsequent sections.

Table 23 – 2014 CWEC and Σ 1998 – 2018

	Electric Consumption (kWh)			Gas Consumption (m ³)		
	Original CWEC x 21	Σ 1998 - 2018	Error %	Original CWEC x 21	Σ 1998 - 2018	Error %
January	3243700	3111665	-4%	299681	281662	-6%
February	2741050	2723604	-1%	224632	228148	2%
March	2684461	2689008	0%	173803	182244	5%
April	2276809	2284231	0%	111699	116545	4%
May	2392388	2373902	-1%	86633	87659	1%
June	2599334	2577389	-1%	77445	77193	0%
July	2928466	2878066	-2%	78175	77986	0%
August	2822352	2788030	-1%	75407	76055	1%
September	2379016	2423374	2%	74259	74202	0%
October	2180436	2227642	2%	94458	99126	5%
November	2492468	2409158	-3%	156489	146602	-7%
December	2829487	2887672	2%	212322	230330	8%
RMSE			553435			8550
MAPE			1.62			3.22
Total	31569966	31373741	-1%	1665002	1677752	1%

Table 24 – 2014 CWEC and Σ 1998 - 2014

	Electric Consumption (kWh)			Gas Consumption (m ³)		
	Original CWEC x 17	Σ 1998 - 2014	Error %	Original CWEC x 17	Σ 1998 - 2014	Error %
January	2625852	2523240	-4%	242599	230399	-5%
February	2218945	2203069	-1%	181845	184916	2%
March	2173135	2172017	0%	140698	147681	5%
April	1843131	1835535	0%	90423	92675	2%
May	1936695	1903463	-2%	70131	71046	1%
June	2104222	2080119	-1%	62694	62520	0%
July	2370663	2314833	-2%	63284	63159	0%
August	2284761	2239423	-2%	61044	61696	1%
September	1925870	1931159	0%	60115	60328	0%
October	1765115	1794872	2%	76466	80751	5%
November	2017712	1950281	-3%	126681	119558	-6%
December	2290537	2346019	2%	171879	188353	9%
RMSE			46758			6794
MAPE			1.70			3.11
Total	25556639	25294031	-1%	1347859	1363081	1%

5.3.1 Electricity

Table 25 – Electricity Load Comparisons

Electricity (kWh)	2014 CWEC x 17	Σ 1998 - 2014	-/+	Error %	2014 CWEC x21	Σ 1998 - 2018	-/+	Error %
Space Cool	602661	621202	-18540	-3%	744464	810549	-66086	-8%
Heat Reject.	765	1306	-541	-52%	945	1952	-1006	-69%
Refrigeration	0	0	0		0	0	0	
Space Heat	124088	124993	-905	-1%	153286	146371	6915	5%
HP Supp.	0	0	0		0	0	0	
Hot Water	0	0	0		0	0	0	
Vent. Fans	298953	294923	4030	1%	369294	366076	3218	1%
Pumps & Aux.	191063	180396	10667	6%	236019	223419	12601	5%
Ext. Usage	6120	6120	0	0%	7560	7560	0	0%
Misc. Equip.	287671	287671	0	0%	355359	355359	0	0%
Task Lights	0	0	0		0	0	0	
Area Lights	414548	414548	0	0%	512088	512089	0	0%
Total	1925870	1931159	-5290	0%	2379016	2423374	-44359	-2%

Errors in electricity loads range between 0% to -52% in the batch of 21 year comparisons. The main source of error is heat rejection, which connects to the heat rejection load of the condenser loop in the chiller. Based on this analysis, the condenser loop is very sensitive to changes in the parameters of the weather file. Two parameters in the climate file could be affecting this. The first is solar radiation and the second is dry bulb temperature. As we've seen in the distribution analysis done in section 5.1, the dry bulb temperature of the CWEC is closely correlated to the dry bulb temperature of the CWEEDS in the summer months. Therefore, there must be inconsistencies in the solar radiation data.

5.3.2 Natural Gas

Table 26 – Natural Gas Load Comparisons

Natural Gas (m ³)	2014 CWEC x 17	Σ 1998 - 2014	-/+	Error %	2014 CWEC x21	Σ 1998 - 2018	-/+	Error %
Space Heat	632141	647325	-15183	-2.4%	780880	793682	-12802	-1.6%
Hot Water	715717	715756	-39	0.0%	884122	884069	52	0.0%
Total	1347859	1363081	-15222	-1.1%	1665002	1677752	-12750	-0.8%

Space heating demand increased slightly by 2.4% when running the total of the 21 years compared to CWEC. This is interesting when compared to the low rise multi-unit residential building, as there was minimal impact on space heating. Both mechanical systems performance are the same in the low-rise building so therefore the factors affecting the increase in space heating are the multi-unit residential building form or building envelope.

5.4 Detached House

5.4.1 Model Verification

The results of the model are verified with both NMBE and CV(RMSE).

Table 27 – Single Family Home Verification Electricity Consumption (kWh)

	Simulated	Normalized	Total Error	Bill	CDD	kWh/CDD
January	402.8089		37.6	440.4	0	
February	357.5524		90.4	447.9	0	
March	390.9529		-37.2	353.8	0	
April	372.7636		60.1	432.8	0	
May	367.0355	196.4	-170.7	237.6	43.4	5.474424
June	415.71	273.8	-142.0	361.3	60.5	5.971405
July	527.2376	759.3	232.0	544.8	167.8	3.246841
August	529.2778	734.9	205.6	468.2	162.4	2.882882
September	440.1941	345.7	-94.5	385.8	76.4	5.049215
October	364.3816		-5.5	358.8	8.2	
November	374.0367		-118.7	255.3	0	
December	395.1467		27.7	422.9	0	
NMBE	1.84555014					
CV(RMSE)	5.86					

The NMBE and CV (RMSE) for electricity consumption are within an acceptable range of the methodology as outlined previously. However, the r^2 value is much lower than expected and does not meet the 75% threshold. This means that the two variables are independent of each other and are not statistically closely fit.




Figure 19 – Single Family Home Electricity Normalized to Modelled Comparison

There could be several reasons why r^2 does not meet the 75% criteria. One is that compared to natural gas, there are more loads in the house which are electricity. Therefore, there is more opportunity to deviate from what was modelled. During the homeowner interviews, it could not be identified why there may have been significantly less electricity used in may compared to other months, other than sporadic occupancy. The details of the model would not be able to capture events like that. Additionally, it is interesting that the months of January with 0 CDD are relatively close to the exact bill amount of August, with 162.4 CDD. It was identified through an interview why this might be the case. However, the homeowner did specify that in colder winter months, occupancy in the house may be higher in proportion to the summer months. This is difficult to quantify without tracking occupancies throughout the year, so therefore was

not modeled. Another potential reasoning is based on the small fan power of the furnace. The fan power of the furnace may be performing more poorly than what was on the manufacturer's documentation and modeled. In a small MURB unit, fan power is minimal and excusable. However, for a large house, the power of the fan could contribute significantly in the winter as the fan needs to work harder to push air to the supplied zones from the size and runs throughout the house. This electricity data was also compared when it was not weather normalized. Figure 20 shows the correlation between the exact bill amounts to the simulated values.




Figure 20 – Single Family Home Electricity Simulated to Bill Comparison

The error between bill value to simulated value decreases from 1221.92 kWh to 694.21 kWh when the normalization of the bills is removed. NMBE decreases to -5.2674 AND CV(RMSE) decreases to 14.72. This suggests two things. The data may not be appropriate to normalize as it may be irregular data, meaning the occupancy patterns or usage patterns are frequently changed. The second issue with this data is the baseload energy consumption. The method used for normalization assumes that the baseload electricity usage (lighting, fans, appliances,

etc.) is a constant number, and the variation is in cooling. Therefore, a dataset with a consistent baseload would be normalized appropriately based on cooling degree days. In this case, it's likely that the baseload energy usage is abnormal and therefore not able to be normalized. In order to identify the baseload of this data, the y-intercept is to be calculated [57]. By comparing the CDD/day and electricity usage/day, the y-intercept between the two values gives the electricity usage/day where the outdoor temperature exceeds the change point and weather dependent loads begin. Figure 21 based on table 28 shows this correlation.




Figure 21 – CDD/Day and Electricity Usage/Day Comparison

Table 28 – Single Family Home CDD and kWh Correlation per Day

	CDD/Day	Electricity Usage/Day	% of Intercept
January	0	14.20774	118%
February	0	15.9975	132%
March	0	11.4129	94%
April	0	14.42767	119%
May	1.4	7.664194	63%
June	2.016667	12.04233	100%
July	5.412903	17.57484	145%
August	5.23871	15.10258	125%
September	2.546667	12.85867	106%
October	0.264516	11.57548	96%
November	0	8.511333	70%
December	0	13.64161	113%

The y-intercept is 12.084 kWh/day. For months without any cooling degree days, the variation in baseload ranges from 132% in February to 70% in November. Based on the review of the baseload, it can be concluded that the data is irregular and normalization is not the limiting factor to the poor fit with the model. This means that the model itself is not representative of the irregular highs and lows in electricity consumption. This is not commonplace for a model to represent, and as the guidelines of NMBE and CV(RMSE) have been met, the accuracy of the model to represent regular usage is verified.

The verification of natural gas is successful and all parameters meet NMBE, CV(RMSE) and R^2 requirements. Natural gas bills are more reliable to normalize as there are only two loads that require natural gas fuel; DHW and heating. Typically, the DHW load would be average of the summer loads where heating is not required. In this case, the DHW baseload with that methodology is 23 m³.

Table 29 - Single Family Home Verification Natural Gas Consumption (m³)

	Simulated	Normalized	Total Error	Bill	HDD	m ³ /HDD
January	559	574	14	516	732.3	0.70476
February	445	435	-10	465	555	0.83728
March	432	434	2	284	554	0.5131
April	384	343	-42	314	437.2	0.71934
May	87	59	-28	53	75.3	0.70948
June	42	35	-6	35	14.8	2.38378
July	22	20	-2	20	0	0
August	22	22	0	22	1.2	18.48
September	44	32	-12	18	41.4	0.43826
October	233	227	-6	100	289.4	0.34482
November	386	387	1	294	494.1	0.5957
December	484	442	-42	332	563.6	0.58842
NMBE	-4.719578046					
CV(RMSE)	14.99					




Figure 22 –Natural Gas Polynomial Line of Fit

June is an outlier month with over three times the m³/HDD. Natural gas usage in June was 35 m³, with 14.8 HDD in the month. Natural gas usage in September was 18 m³, with 41.4 HDD in the month. Homeowners were interviewed to understand why this could be the case and they were unsure. However the reasoning for that month being an outlier is likely an increase in DHW usage as the heating was running on typical set points. Therefore, it would be worthwhile to look more into the intercept of this to identify the baseload.

Table 30 – Single Family Home CDD and kWh Correlation per Day

	HDD/Day	m³/Day	% of Intercept
January	23.62258	16.65	2488%
February	19.82143	16.60	2480%
March	17.87097	9.17	1370%
April	14.57333	10.48	1567%
May	2.429032	1.72	258%
June	0.493333	1.18	176%
July	0	0.65	97%
August	0.03871	0.72	107%
September	1.38	0.60	90%
October	9.335484	3.22	481%
November	16.47	9.81	1466%
December	18.18065	10.70	1599%




Figure 23 - HDD/Day and m³/Day Comparison

The data shows that the baseload of natural gas is 0.672 m³/day. When matched to the original bills in the summer months of July and August, it is within 97% to 107% of this baseload. Table 31 is the comparison between the modelled load and the actual load.

Table 31 – Model Matched to Domestic Hot Water Usage

DHW (m³)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Model	21	19	21	22	22	20	22	22	20	22	19	21	252
Actual	21	19	21	20	21	20	21	21	20	21	20	21	244
% Diff	98%	98%	98%	91%	94%	100%	95%	95%	100%	94%	105%	98%	97%
Space Heat (m³)													
Model	528	417	400	353	59	19	0	0	21	202	357	452	2807
Actual	553	416	413	322	38	15	-1	1	12	206	367	421	3318
% Diff	-95%	-100%	-97%	-109%	-155%	-123%	0%	0%	-172%	-98%	-97%	-107%	-85%

The baseload DHW is derived from the original bills and applied for each month. Depending on the number of days in the given month, a volume of water used daily is multiplied by the total number of days. Annually, the model overestimates 3% of the baseload DHW, with a range between 9% overestimation to 5% underestimation monthly. This is reasonably accurate and the DHW can be subtracted from the rest of the natural gas usage to derive what was modeled for space heating. From this, space heating is found to be within 15% underestimation of the actual space heating usage. The model ranges within 72% overestimation in September to 5% underestimation in January.

5.4.2 Electricity

As the model is verified, the verified monthly electricity consumption is compared to the monthly electricity consumption of AMY and CVEC. However, as was previously determined in the sections above, the electricity usage is not normal and therefore does not represent a consistent baseload as would be modelled. Therefore, the actual bill data can not be compared to the modelled values of either the CVEC or the 17 year total. The typical comparison of monthly electricity and natural gas consumption for CVEC for the respective set of years is shown in tables 32 and 33.

Table 32 - 2014 CVEC and Σ 1998 - 2014

	Electric Consumption (kWh)		Error %	Gas Consumption (m ³)		Error %
	Original CVEC x 21	Σ 1998 - 2014		Original CVEC x 21	Σ 1998 - 2014	
January	6918	6862	-1%	357971	340052	-5%
February	6178	6168	0%	297114	293592	-1%
March	6620	6636	0%	254952	259174	2%
April	6162	6156	0%	175447	172912	-1%
May	6047	6118	1%	82943	82506	-1%
June	6827	6686	-2%	28769	28331	-2%
July	8157	7858	-4%	14367	15087	5%
August	7562	7877	4%	13682	15140	10%
September	6026	6434	7%	30226	30646	1%
October	6119	6177	1%	113727	117753	3%
November	6260	6228	-1%	204143	192321	-6%
December	6715	6757	1%	284514	300302	5%
Total	79591	79957	0%	1857852	1847819	-1%

Table 33 - 2014 CWEC and Σ 1998 - 2018

	Electric Consumption (kWh)			Error	Gas Consumption (m ³)			Error
	Original CWEC x 21	Σ 1998 - 2018	%		Original CWEC x 21	Σ 1998 - 2018	%	
January	8546	8469	-1%		442199	417072	-6%	
February	7631	7614	0%		367023	361026	-2%	
March	8178	8200	0%		314941	320043	2%	
April	7612	7611	0%		216728	215742	0%	
May	7470	7584	2%		102459	99077	-3%	
June	8433	8272	-2%		35538	33412	-6%	
July	10077	9420	-7%		17747	18356	3%	
August	9341	9460	1%		16901	18446	9%	
September	7443	7947	7%		37338	35419	-5%	
October	7559	7338	-3%		140486	141183	0%	
November	7733	7133	-8%		252176	234594	-7%	
December	8295	7426	-11%		351458	367887	5%	
Total	98318	96473	-2%		2294993	2262257	-1%	

Table 34 – Annual Electricity Load Comparisons

Annual Electricity (kWh)	2014 CWEC x 17	Σ 1998 - 2014	-/+	Error %	2014 CWEC x21	Σ 1998 - 2018	-/+	Error %
Space Cool	5171	5535	-363	-7%	6388	7463	-1075	-16%
Heat Reject.	0	0	0		0	0	0	
Refrigeration	0	0	0		0	0	0	
Space Heat	0	0	0		0	0	0	
HP Supp.	0	0	0		0	0	0	
Hot Water	0	0	0		0	0	0	
Vent. Fans	5357	5377	-20	0%	6618	3734	2884	56%
Pumps & Aux.	2135	2118	17	1%	2638	2601	37	1%
Ext. Usage	0	0	0		0	0	0	
Misc. Equip.	43792	43792	0	0%	54096	54096	0	0%
Task Lights	0	0	0		0	0	0	
Area Lights	23135	23135	0	0%	28579	28579	0	0%
Total	79591	79957	-366	0%	98318	96473	1845	2%

The electricity consumption over 17 years using CWEC 2014 is less than 1% error when compared to the sum of the individual year simulations. The space cooling was underestimated by 7%. Interestingly for this home, the cooling load is relatively minimal and the error in total cooling load is almost the entire cooling load for a house for a year. The load comparison shifts to 2% overestimation when compared to the period of 1998 to 2018. The errors here are primarily in space cooling and fans, where the CWEC overestimates ventilation fans by roughly 56% and space cooling is underestimated by 16%. In eQUEST, the power of the circulation fan for the AC unit is grouped under vent fans, while the electricity used for the compressor and the cooling capacity is grouped under cooling. Therefore, the adverse relationship between the ventilation fan capacities being overestimated may have more to do with the natural gas consumption of the furnace rather than the air conditioner. This can be reviewed in the next section.

5.4.3 Natural Gas

Table 35 compares the errors between the 2014 CWEC file result and the mean of the set of 17 year and 21 years to the verified normalized natural gas modelled consumption.

Table 35 – Comparison of Annual Means

Annual Natural Gas Load (m³)	Verified Model	2014 CWE	1998			1998			2002				
			-	-/+		-	-/+		-	-/+			
					2014			2018			2018		
Space Heat	2807	2808	1	0.03%	2792	17	0.59%	2765	-43	-2%	2265	-542	-19%
Hot Water	252	252	0	0.01%	252	0	0.01%	252	0	0%	204	-48	-19%
Total	3059	3060	1	0.03%	3043	17	0.54%	3016	-43	-1.40%	2469	-590	-19.29%

The verified model is most closely matched to the 2014 CWEC, at 99.07 % accuracy. In comparison to the mean of the dataset of 1998 to 2014, it was 99.46% accuracy from the verified model for total loads, which is very close to the modelled amount. In comparison to the mean of 1998 to 2018 and 2002 to 2018, the 2014 CWEC and 1998 to 2014 AMYs were a closer fit. A point to note is that the 1998 to 2018 dataset and 2002 to 2018 dataset represents a lower space heating demand. This is in line with the understanding previously mentioned in the literature review that for cold climate buildings, total heating degree days are slowly decreasing [2]. The average amount of heating degree days from 1998 to 2018 was 3611 at a set point of 18°C. The total amount of heating degree days in 2018 was 3765, which is 4.3% higher than the average. When compared against the running average of heating degree days from 2018 to 1940, the trend line towards additional heating degree days steadily increases the more years are added. Figure 24 shows this progression.




Figure 24 – Running Average of Heating Degree Days (1940 to 2018)

5.5 Energy Star Detached House

This hypothetical Energy Star compliant home is following a prescriptive BOP however will be modelled to compare the energy consumption changes with the verified single family home model. Some of the key upgrades to the single family home, as previously listed in the methodology section, include improvements on the envelope and a focus on infiltration. One parameter changed in the Energy Star model compared to the single family home is the addition of the energy recovery ventilator (ERV). In the winter, an ERV is used as a heat exchanger between heated stale air and cool fresh air from the outdoors, and is used as a partial preheat to the outdoor air coming into the furnace. In the summer, an ERV is used as a heat exchanger between cooled stale air and warm fresh air from the outdoor, to partially cool the outdoor air. Based on a 2019 study of ERV performance in cold climates, an ERV can provide up to a 3°C increase in supply air temperature and reduce whole house energy savings by 4.7% in the winter. The fenestration of the Energy Star building is upgraded. The windows are to a triple pane low-e argon filled window with a u-value of 1.4 W/m² K. The infiltration of an Energy Star home is required to outperform typical infiltration trades of a single family home as based on typical Energy Star requirements. The Energy Star home modelled has an infiltration rate of 0.35 L/s.m². This target is very stringent and requires a careful review of the continuous air barrier in design and construction. Tables 36 and 37 show that the range in errors between the CWEC and AMY datasets. The shift between the CWEC data compared to the sum of the 17 years is between 5% to -6% monthly, and errors shift between 7% to -5% monthly when compared to the sum of the 21 years. The Energy Star is not a verified model and accuracy cannot be confirmed for any weather file tested.

Table 36 - 2014 CWEC and Σ 1998 – 2018

	Electric Consumption (kWh)		Error %	Gas Consumption (m ³)		Error %
	Original CWECC x 21	Σ 1998 - 2018		Original CWECC x 21	Σ 1998 - 2018	
January	9328	9276	-1%	8692	8284	-5%
February	8468	8417	-1%	7164	7187	0%
March	9384	9326	-1%	6255	6508	4%
April	8916	8848	-1%	4429	4373	-1%
May	8797	8817	0%	2096	2151	3%
June	9328	9113	-2%	745	715	-4%
July	10646	10443	-2%	466	473	2%
August	10379	10674	3%	465	471	1%
September	8822	9297	5%	650	631	-3%
October	9008	8988	0%	2477	2466	0%
November	8931	8858	-1%	4693	4450	-5%
December	9381	9324	-1%	6748	7250	7%
Total	111389	111381	0%	44879	44960	0%

Table 37 - 2014 CWEC and Σ 1998 - 2014

	Electric Consumption (kWh)		Error %	Gas Consumption (m ³)		Error %
	Original CWECC x 17	Σ 1998 - 2014		Original CWECC x 17	Σ 1998 - 2014	
January	7552	7544	0%	7036	6658	-6%
February	6855	6853	0%	5800	5761	-1%
March	7596	7590	0%	5063	5157	2%
April	7218	7218	0%	3586	3540	-1%
May	7122	7172	1%	1697	1707	1%
June	7551	7421	-2%	603	597	-1%
July	8618	8430	-2%	377	383	2%
August	8402	8586	2%	376	381	1%
September	7142	7386	3%	526	530	1%
October	7293	7319	0%	2005	2089	4%
November	7230	7224	0%	3799	3598	-5%
December	7594	7583	0%	5463	5741	5%
Total	90172	90326	0%	36331	36141	-1%

5.5.1 Electricity

Table 38 – Annual Electricity Load Comparisons

Annual Electricity (kWh)	2014 CWEC	Mean of 1998 - 2014	-/+	Error %	Mean of 1998 - 2018	-/+	Error %
Space Cool	247	257	10	4%	281	34	14%
Heat Reject.	0	0	0		0	0	
Refrigeration	0	0	0		0	0	
Space Heat	0	0	0		0	0	
HP Supp.	0	0	0		0	0	
Hot Water	0	0	0		0	0	
Vent. Fans	889	889	-1	0%	862	-28	-3%
Pumps & Aux.	231	230	0	0%	224	-7	-3%
Ext. Usage	0	0	0		0	0	
Misc. Equip.	2576	2576	0	0%	2576	0	0%
Task Lights	0	0	0		0	0	
Area Lights	1361	1361	0	0%	1361	0	0%
Total	5304	5313	9	0%	5304	0	0%

The absolute error in electricity between the 2014 CWEC and both the 17 year and 21 year means is less than 1%. The energy star building has the lowest consumption of all the buildings modelled so very moderate changes occur to the building's space cooling load. The main differences between the two sets of data are the space cooling load estimates in the mean of the 21 years. As previously mentioned, cooling degree days are increasing and heating degree days are decreasing in Toronto. Figure 25 shows the running average ratio of cooling degree days to heating degree days for each year included in the 21 year dataset. The running average starts in 1938 and cumulates each year onwards to 2018. There is a slight increase in the ratio of CDD to HDD. In particular, the average of this ratio from the year 2018 to 2015, which are the additional years added to the CWEEDS, is 7.22% higher than the average from 1998 to 2014.




Figure 25 – Running Average of CDD/HDD Ratio for Toronto

5.5.2 Natural Gas

Table 39 – Annual Natural Gas Load Comparisons

Natural Gas (m ³)	2014 CWEC	Mean of 1998 - 2014	-/+	Error %	Mean of 1998 - 2018	-/+	Error %
Space Cool	0	0	0		0	0	
Heat Reject.	0	0	0		0	0	
Refrigeration	0	0	0		0	0	
Space Heat	1886	1874	-11	-1%	1889	4	0%
HP Supp.	0	0	0		0	0	
Hot Water	251	251	0	0%	251	0	0%
Vent. Fans	0	0	0		0	0	
Pumps & Aux.	0	0	0		0	0	
Ext. Usage	0	0	0		0	0	
Misc. Equip.	0	0	0		0	0	
Task Lights	0	0	0		0	0	
Area Lights	0	0	0		0	0	
Total	2137	2126	-11	-1%	2141	4	0%

With natural gas, the 2014 CWEC better estimates the 1998 to 2018 weather conditions, with only 3.8 annual m³ of error. As the u-value of the windows increase and the ERV efficiency was

increased, 1998 to 2018 appears to better correlated with the CWeC as the mean heating load would be lower during these years based on a lower mean HDD. This is interesting to note as it is possible that for energy efficient buildings with lower natural gas consumption for heating, the mean of the 1998 to 2014 years may actually produce a more favourable EUI. This is based on more savings achieved with more heating degree days and less cooling degree days. This would be the case for any building where the cooling load is far lower than the heating load, which is typical for a climate like Toronto. This is an interesting finding as this may be one opportunity to compare which energy savings measure to focus on as the climate shifts. If the upward shift in CDDs continues, future work should be done to compare the performance of energy conservation measures and new years of climate data.

5.5.3 Comparison to Non-Energy Star Home

In order to look more into whether the energy conservation measures in an Energy Star home is possibly better represented by the mean of the years 1998 to 2014, this section compares the performance with the original verified single family home with outdoor air included with the new Energy Star home performance. Table 40 summarizes this comparison and groups the data into means of each multi-year data, as previously shown in the Energy Star portion.

Table 40 – Electricity and Natural Gas Comparison with Energy Star and Non-Energy Measures

	Load	2014 CWECC	Mean of 1998 - 2014	-/+	Error	Mean of 1998 - 2018	-/+	Error
Electricity (kWh)								
Non-Energy Star	Space Cool	263	275	12	5%	303	39	15%
	Vent. Fans	1255	1255	-1	0%	1256	0	0%
	Pumps & Aux.	231	230	0	0%	230	-1	-1%
	Misc. Equip.	2576	2576	0	0%	2576	0	0%
	Area Lights	1361	1361	0	0%	1361	0	0%
	Total	5686	5697	11	0%	5725	39	1%
Energy Star	Space Cool	247	257	10	4%	281	34	14%
	Vent. Fans	889	889	-1	0%	862	-28	-3%
	Pumps & Aux.	231	230	0	0%	224	-7	-3%
	Misc. Equip.	2576	2576	0	0%	2576	0	0%
	Area Lights	1361	1361	0	0%	1361	0	0%
	Total	5304	5313	9	0%	5304	0	0%
Natural Gas (m³)								
Non-Energy Star	Space Heat	2835	2819	-17	-1%	2794	-42	-1%
	Hot Water	252	252	0	0%	252	0	0%
	Total	3087	3071	-17	-1%	3045	-42	-1%
Energy Star	Space Heat	1886	1874	-11	-1%	1889	4	0%
	Hot Water	251	251	0	0%	251	0	0%
	Total	2137	2126	-11	-1%	2141	4	0%
Non-Energy Star	Total Energy (ekWh)	28055	27949	127	0.46%	28134	79	0.28%
Energy Star	Total Energy (ekWh)	27673	27565	126	0.46%	27713	40	0.14%

6.0 CREATED CWEC COMPARISONS

Using a typical year weather file has been the standard for energy modelling simulations in general industry applications. In order to avoid any inconsistencies in the methodologies of how individual companies choose weather files, typically current Toronto simulations are done with a 2014 CWEC. This research acknowledges that one weather file may be needed to keep consistency between how different energy modellers model weather. In addition, City of Toronto requires that a CWEC file be used for all city submitted models. Reviewing one of the original research questions, this chapter is an answer to the following; When 2015 to 2018 is added to the dataset, does the final output of the CWEC change? Are those changes impactful on the energy performance of the energy model? If those incremental changes are significant, should an AMY weather file be created every year to support better estimated simulated energy? As targets are being shifted away from comparisons between a baseline model and design model, and towards an absolute target, the weather file in the energy model needs to be as accurate as possible to ensure all savings are accounted for based on the most updated weather data. In order to keep the format of a single run weather file, an up to date CWEC was created to include data from the most recent full calendar year. The following typical meteorological months changed within the updated CWEC when 4 additional years were added. In the span of those years, only data from the original CWEEDS set was selected.

Table 41 – Changed Typical Meteorological Months of 1998 to 2018 CWeC

Month	1998 - 2014	1998 - 2018	changed
01	1999	2007	Y
02	2004	2004	N
03	2006	2006	N
04	2009	2009	N
05	2006	2001	Y
06	2001	2010	Y
07	2013	2013	N
08	2011	1998	Y
09	2003	1998	Y
10	2010	2014	Y
11	2000	2000	N
12	2003	2004	Y

In order to compare the correlations between the previous CWeC and the created CWeC, figures 26 and 27 show the comparison in the distribution of hourly dry bulb temperatures in the original CWeC to the CWeED 1998 to 2014 and the created CWeC to the CWeED 1998 to 2018. The figures show that both sets of CWeC are well correlated, however the errors between the standard deviations and means of the old CWeC and its CWeED years are actually smaller than the errors for the created CWeC. This is interesting as the methodology for creating these two CWeC is exactly the same, with the same weighting parameters and using the same FS statistic calculations.




Figure 26 – Distribution comparison between hourly DBT of 2014 CWEC and CWEEDS




Figure 27 – Distribution comparison between hourly DBT of 2018 CWEC and CWEEDS

The comparison of these two sets of standard deviations and means are in table 42.

Table 42 – Dry Bulb Temperature (°C) Distribution Comparison

Years	St Dev	Mean	Years	St Dev	Mean	St Dev Error	Mean Error
2014 CWEC	10.859	9.142	1998 to 2014	10.893	9.108	0.034	-0.034
2018 CWEC	10.802	9.321	1998 to 2018	10.973	9.168	0.171	-0.153

The difference in the two errors is not large but is not exactly matched. In order to understand how including the last 4 full years of weather data would impact the energy calculations, the following sections compare the CWEC 2014 performance with those of the created CWEC 2018.

6.1 Toronto Low Rise MURB

The following results were generated for the low rise model with CWEC 2014 and CWEC 2018.

Table 43 - Electricity and Gas Consumption Variation

	Electric Consumption (kWh)		Error %	Gas Consumption (m ³)		Error %
	Original CWEC	Created CWEC		Original CWEC	Created CWEC	
January	38646	38737	0%	10569	9423	-11%
February	35072	35199	0%	8532	8475	-1%
March	39719	39955	1%	7317	7253	-1%
April	39580	39933	1%	5007	4949	-1%
May	45474	45178	-1%	3241	3057	-6%
June	50217	50627	1%	2557	2503	-2%
July	57343	58819	3%	2331	2352	1%
August	55358	57057	3%	2131	2171	2%
September	45933	48999	7%	2210	2220	0%
October	40741	40883	0%	3595	3538	-2%
November	37878	38027	0%	6165	6165	0%
December	38682	38628	0%	8188	9286	13%
Total	524643	532044	1%	61843	61393	-1%

Minimal differences are observed over the entire year, however changes month to month are significant. For simulations looking to estimate overall seasonal averages or monthly averages, this may pose to be an issue. May to August is considered as the cooling season and the electricity usage ranges from 3% to -1% during this time. November to March is considered as the heating season and natural gas usage variation ranges from 13% to -11%. To investigate the discrepancy in the variances between these two conditioning periods, the variations in loads are broken down in table 44.

Table 44 – Load Changes between CWeC 2014 to CWeC 2018.

Gas (m³)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Heat	-15%	0%	0%	0%	-44%	-86%			-19%	-6%	0%	21%	-1%
Hot Water	-1%	-2%	-2%	-2%	-1%	0%	1%	2%	2%	1%	0%	-1%	0%
Total	-11%	-1%	-1%	-1%	-6%	-2%	1%	2%	0%	-2%	0%	13%	-1%

Electricity (kWh)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	16%	10%	9%	9%	-4%	4%	7%	8%	24%	5%	8%	-174%	8%
Vent. Fans	0%	0%	0%	0%	-1%	-3%	-2%	0%	-1%	-1%	0%	1%	0%
Pumps & Aux.	4%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	6%	5%
Misc. Equip.	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Area Lights	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Total	0%	0%	1%	1%	-1%	1%	3%	3%	6%	0%	0%	0%	1%

6.2 Toronto High Rise MURB

Figure 28 and Table 45 summarize the changes in heating and cooling loads from CWEC 2014 to CWEC 2018. This comparison is broken down into monthly loads and errors between those months. November, June, July, April, and March did not change in the updated CWEC, therefore the heating in those months stayed consistent with CWEC 2014. The data used for this is exactly the same as the CWEEDS original dataset so the variation may have to do with the transition between months. For example, the last weather data point in January may impact the calculation of how long that air takes to heat for the first hour in February.




Figure 28 – CWEC MURB Space Heating (m³)

Table 45 – CWEC Space Heating Natural Gas Consumption

<i>Natural Gas Consumption (m³)</i>	<i>CWEC 2014 Space Heat</i>	<i>CWEC 2018 Space Heat</i>	<i>Difference</i>	<i>% Difference</i>
<i>Jan</i>	10575	11844	-1269	-12%
<i>Feb</i>	7388	7388	0	0%
<i>Mar</i>	4665	4665	0	0%
<i>Apr</i>	1853	1853	0	0%
<i>May</i>	578	642	-64	-11%
<i>Jun</i>	316	332	-16	-5%
<i>Jul</i>	227	225	2	1%
<i>Aug</i>	93	74	19	20%
<i>Sep</i>	147	169	-22	-15%
<i>Oct</i>	922	968	-46	-5%
<i>Nov</i>	3931	3931	0	0%
<i>Dec</i>	6490	5581	909	14%
<i>Total</i>	37185	37557	-372	-1%




Figure 29 – CWEC MURB Space Cooling (kWh)

Table 46 – CWEC Space Cooling Electricity Consumption

<i>Electricity Consumption (kWh)</i>	<i>CWEC 2014 Space Cool</i>	<i>CWEC 2018 Space Cool</i>	<i>Difference</i>	<i>% Difference</i>
<i>Jan</i>	629	850.15	221	35%
<i>Feb</i>	1054	1069.54	16	2%
<i>Mar</i>	3862	3903.06	41	1%
<i>Apr</i>	9124	9189.48	66	1%
<i>May</i>	28747	28118.09	-629	-2%
<i>Jun</i>	48560	47240.11	-1320	-3%
<i>Jul</i>	64682	64445.52	-236	0%
<i>Aug</i>	59842	60565.49	724	1%
<i>Sep</i>	35451	41154.29	5704	16%
<i>Oct</i>	8363	8558.42	196	2%
<i>Nov</i>	2293	2294.75	2	0%
<i>Dec</i>	894	644.71	-249	-28%
<i>Total</i>	263498	268034	4535	2%

September is an outlier month in both the low rise and high rise MURB models. In the analysis of low rise in section 5, the September month selected by the CWEC was the second lowest month of total CDD from within the CWEEDS. In the case here, the variance is within 5704 kWh lower than the created CWEC. This impact could also be more evidence as there is a stronger weight on the performance of the envelope for the MURB building type, as the thermal performance of spandrel, window wall and curtain wall is weaker than that of an opaque wall. For a 40% WWR building, this impact on space cooling is impactful for buildings with significant glazing on the north, east and west façade.

6.3 Single Family Home

A comparison between the 2014 CWEC and 2018 CWEC is presented in table 47 for the verified single family home.

Table 47 – Single Family Home Created CWEC Comparisons

	Electric Consumption (kWh)			Gas Consumption (m ³)		
	Original CWEC	Created CWEC	Error %	Original CWEC	Created CWEC	Error %
January	406.93	400.00	-2%	590	528	-11%
February	363.39	363.13	0%	489	488	0%
March	389.42	388.87	0%	420	415	-1%
April	362.47	362.01	0%	289	285	-1%
May	355.70	358.46	1%	137	121	-12%
June	401.58	358.95	-11%	47	39	-19%
July	479.84	476.91	-1%	24	25	4%
August	444.82	467.81	5%	23	25	9%
September	354.45	379.82	7%	50	41	-20%
October	359.95	357.19	-1%	187	181	-4%
November	368.26	368.16	0%	336	336	0%
December	395.00	400.23	1%	469	522	11%
Total	4681.81	4681.52	0%	3060	3004	-2%

As the single family home model is verified, the actual accuracy of the original CWEC compared to the newly created CWEC is compared. In reality, a model is built prior to the construction of the building. In this way, the measurement and verification of the model would always be gapped in years from the weather file used for simulation. However, in the case that a model is required after the building is constructed, this analysis is useful to determine whether including

the latest calendar year is relevant to building a better correlated and calibrated model. From table 47, the error between electricity is very low, with no more than 11% deviation in the month of June. Total absolute error between months is between 0.1 kWh to 42.63 kWh. This averages to an annual total error of only 0.29 kWh. For natural gas, there is a greater range in absolute errors between 0.16 m³ to 61.88 m³, for an annual absolute error of 55.78 m³. The reason why the deviation in electricity is so low is that there are no weather dependent variables for electricity other than cooling, and the cooling load in a building is minimal compared to the rest of the remaining baseload. In addition, the building modeled has an AC unit of COP 4, which is better than most homes. For an energy efficient building with minimal cooling load, electrical accuracy is not generally impacted by small changes in weather data. In order to review discrepancies between the individual loads and the verified model, figures 29 to 32 show the differences in loads between the 2014 CWeC, 2018 CWeC and the verified model.




Figure 30 – Monthly Cooling Electricity (kWh)




Figure 31 – Monthly Heating Natural Gas (m³)




Figure 32 – Monthly Cooling (kWh)




Figure 33 – Monthly Heating (m³)

6.4 Alternative CWEC Years

In order to better understand how the time period of creating a CWEC could impact the output of the model, table 48 provides an overview of the various CWECs created using the dataset years in the header column.

Table 48 – Comparisons between CWEC from CWEEDS datasets

Month	1998 - 2011	1998 - 2012	1998 - 2013	1998 - 2014	1998 - 2015	1998 - 2016	1998 - 2017	1998 - 2018
01	2000	2001	2007	1999	2007	2007	2007	2007
02	2004	2004	2004	2004	2005	2005	2004	2004
03	2002	1998	2006	2006	2006	2006	2006	2006
04	2009	2009	2009	2009	2009	2009	2009	2009
05	2006	2006	2006	2006	2006	2001	2006	2001
06	2010	2001	2010	2001	2010	2010	2010	2010
07	1998	1998	2013	2013	1998	1998	1998	2013
08	2011	2011	2011	2011	2013	1998	1998	1998
09	2003	2003	2003	2003	1999	1998	1998	1998
10	2010	2010	2010	2010	2010	2014	2014	2014
11	1999	1999	1998	2000	2000	1999	1999	2000
12	1999	2003	2003	2003	2003	2003	2004	2004
Annual CDD	315	331	397	413	316	313	325	395
Annual HDD	3292	3180	3215	3356	3193	3189	3190	3341
Total Annual Irradiance (kJ/m ²)	494468	4968917	4926688	4983446	4991719	4983631	4986052	4998295

1998 to 2014 is the original CWEC. 1998 to 2018 is the created CWEC compared in this section.

All other CWECs are created to be compared with monthly and annual CDD, HDD and total irradiance. No typical months were selected from the created AMY data, everything was from previous CWEEDS data Environment Canada collected. Therefore, any of this data selected was

run with SUNY radiation data and not NREL, and that potential bias is eliminated. A full breakdown of monthly HDD, CDD and total irradiance is provided.

Table 49 – Monthly and Annual HDD, CDD and Total Irradiance kJ/m²

1998 - 2011	CDD	HDD	Solar	1998 - 2012	CDD	HDD	Solar	1998 - 2013	CDD	HDD	Solar
2000	0	731	198317	2001	0	670	185491	2007	0	641	164866
2004	0	617	264362	2004	0	617	264362	2004	0	617	264362
2002	0	545	400563	1998	0	486	431554	2006	0	520	444432
2009	1	308	520023	2009	1	308	520023	2009	1	308	520023
2006	25	26	636178	2006	25	26	636178	2006	25	26	636178
2010	57	21	634835	2001	73	21	646308	2010	57	21	634835
1998	91	1	675235	1998	91	1	675235	2013	173	0	676406
2011	120	0	564737	2011	120	0	564737	2011	120	0	564737
2003	21	48	429109	2003	21	48	429109	2003	21	48	429109
2010	0	237	291522	2010	0	237	291522	2010	0	237	291522
1999	0	361	181261	1999	0	361	181261	1998	0	392	157081
1999	0	397	148326	2003	0	405	143137	2003	0	405	143137
Annual	315	3292	4944468		331	3180	4968917		397	3215	4926688

1998 - 2014	CDD	HDD	Solar	1998 - 2015	CDD	HDD	Solar	1998 - 2016	CDD	HDD	Solar
1999	0	746	187464	2007	0	641	164866	2007	0	641	164866
2004	0	617	264362	2005	0	557	240222	2005	0	557	240222
2006	0	520	444432	2006	0	520	444432	2006	0	520	444432
2009	1	308	520023	2009	1	308	520023	2009	1	308	520023
2006	25	26	636178	2006	25	26	636178	2001	13	111	648743
2001	73	21	646308	2010	57	21	634835	2010	57	21	634835
2013	173	0	676406	1998	91	1	675235	1998	91	1	675235
2011	120	0	564737	2013	93	0	622076	1998	109	0	603297
2003	21	48	429109	1999	49	49	439425	1998	41	39	463782
2010	0	237	291522	2010	0	237	291522	2014	1	225	263798
2000	0	428	179768	2000	0	428	179768	1999	0	361	181261
2003	0	405	143137	2003	0	405	143137	2003	0	405	143137
Annual	413	3356	4983446		316	3193	4991719		313	3189	4983631

1998 - 2017	CDD	HDD	Solar	1998 - 2018	CDD	HDD	Solar
2007	0	641	164866	2007	0	641	164866
2004	0	617	264362	2004	0	617	264362
2006	0	520	444432	2006	0	520	444432
2009	1	308	520023	2009	1	308	520023
2006	25	26	636178	2001	13	111	648743
2010	57	21	634835	2010	57	21	634835
1998	91	1	675235	2013	173	0	676406
1998	109	0	603297	1998	109	0	603297
1998	41	39	463782	1998	41	39	463782
2014	1	225	263798	2014	1	225	263798
1999	0	361	181261	2000	0	428	179768
2004	0	431	133983	2004	0	431	133983
Annual	325	3190	4986052		395	3341	4998295

The total amount of annual CDD varies from 313 based on 1998 to 2016 to 413 based on 1998 to 2014. In the space of the 8 sets of CWEC years analyzed, there is a 27% variance in total CDD. What's interesting to note is that CWEC 2014 is the highest in this range of CDD. However, when 2015 data is added, the CDD drops to 316. This data is impactful to the performance of a building which is targeting a specific peak cooling load to be presented in the model. The total amount of annual HDD varies from 3180 in 1998 to 2012, to 3356 in 1998 to 2014, which represents a 5% variance. Again, the maximum amount of HDD represented in this period is shown in the 2014 conditions. For total irradiance, the maximum and minimum ranges from 4926688 to 4998295 kJ/m². Given that the same FS statistics and weighting parameters were used to calculate each CWEC, the variance between each is a direct result of each additionally added year to the set of CWEEDS data. As a whole, the variation between these CWEC sets are significantly more than the variation between the sums or means of the AMY years to the

calculation using the CWEC. The timing of when the CWEC is chosen then is especially critical, as the variation as shown in figures 34 to 36 are significant.




Figure 34 – Annual CWEC Solar Irradiance Trends




Figure 35 – Annual CWEC HDD Trends




Figure 36 – Annual CWEC CDD Trends

In order to understand how the difference in CDD, HDD and irradiance impact the performance of the model, the single family verified home has been run with each CWECC and results are shown in Table 50.

Table 50 – Single Family Home CWECC Analysis

	Years	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	Rank
Cooling (kWh)	Verified	0	0	0	0	22	76	162	162	95	0	0	0	518	0
	1998 - 2011	0	0	0	0	5	36	101	93	22	0	0	0	257	8
	1998 - 2012	0	0	2	0	6	64	103	92	22	0	0	0	289	5
	1998 - 2013	0	0	0	0	6	37	119	90	22	0	0	0	274	7
	1998 - 2014	0	0	0	0	5	63	121	92	22	0	0	0	304	2
	1998 - 2015	0	0	0	0	6	36	100	96	47	0	0	0	284	6
	1998 - 2016	0	0	0	0	11	29	101	114	45	0	0	0	301	3
	1998 - 2017	0	0	0	0	6	37	100	113	45	0	0	0	300	4
	1998 - 2018	0	0	0	0	10	29	119	111	45	0	0	0	314	1
Heating (m3)	Verified	549	436	421	375	81	39	22	22	41	224	376	473	3059	0
	1998 - 2011	565	489	441	290	136	37	25	23	51	188	293	467	3006	2
	1998 - 2012	531	484	392	280	134	47	24	23	51	188	292	465	2909	7
	1998 - 2013	527	487	415	284	134	37	24	23	51	188	324	463	2957	6
	1998 - 2014	590	489	420	289	137	47	24	23	50	187	336	469	3060	1
	1998 - 2015	527	479	418	284	135	37	25	25	48	186	336	466	2967	5
	1998 - 2016	526	478	417	283	119	38	25	24	40	179	292	465	2886	8
	1998 - 2017	527	487	414	284	134	37	25	24	41	181	293	521	2969	4
	1998 - 2018	528	488	415	285	121	39	25	25	41	181	336	522	3004	3

In ranked order from least to most variance from the verified year of 2018, the original CWECC from 1998 to 2014 is closest to the modelled values for both heating natural gas load. The 1998 to 2018 CWECC is closest to the modelled value for cooling electricity load. There is a range in cooling load of 57 kWh across all the created CWECC files. There is a range in heating load of 151 m³ across all created CWECC files. The variations in cooling and heating indicate an inconsistency in the generated heating and cooling load of a single family home simulation. It is compelling to

note that additional years added to the CWEEDS could change heating and cooling load results up to 4,837 ekWh in heating and cooling load in a single family home. Such variations are significant and warrant regular updates to the CWEEDS to determine whether a new CWEK file should be created.

7.0 FUTURE WORK AND CONCLUSIONS

7.1 Future Work

This work is a step towards more validations using AMY weather files and comparisons between building types. There is further work that can be done to better understand the relationship between simulations using typical year weather files and actual meteorological year weather files. A verified model of a single family home was created. It would be beneficial to create a verified model for all the other building types; high rise residential, low rise residential and Energy Star homes. This work could also be stretched to the commercial and retail sectors to include energy simulations of existing buildings. The benefit of having a verified model of these building types and performing this simulation is being able to compare the accuracy of the AMY files to the accuracy of the CWEC files. In addition, this work would be beneficial to be replicated for future years and additional Canadian cities. One key element to this research that can be elaborated on is the period of time in which the CWEC should be regularly updated. As shown in the section with varied spans in years in CWEC calculations, there should be a strategic review of the periods of time in which a CWEC update is required. As shown in this research, the CWEC accuracy differs from building to building, and a thorough review of this would be necessary. Another point of data that could be included is real solar radiation data at the location of the model. This would take a large investment and significant time to obtain ground level measurement in comparison with SUNY and NREL.

7.2 Conclusions

This research answers the following two questions;

- 1) What are the energy consumption impacts of simulating individual years of 1998 to 2014, compared to the typical year weather file last released, CWeC 2016?
 - a. How does this differ between a high rise residential building, low rise residential building, and a single family home?
- 2) When 2015 to 2018 is added to the dataset, does the final output of the CWeC change?
 - a. Are those changes impactful on the energy performance of the energy model?
 - b. If those incremental changes are significant, should an AMY weather file be created every year to support better estimated simulated energy?

In order to conduct this work, a total of 96 energy simulations were performed on four different types of buildings; low-rise residential, high-rise residential, single family home and Energy Star single family home. 42 individual AMY weather files were created, and 8 CWeC files. Models were built based on city specific parameters and the single family home was verified against 2018 utility and climate data.


To answer the first research question, simulating 1998 to 2014 AMY years compared to the latest CWeC shows a monthly variability in total energy consumption of 18% for high rise residential building, 16% for low rise buildings, 14% for single family homes and 12% for Energy Star homes. Annual variability in total energy consumption ranges by only 2%. The impacts on energy when using a CWeC file are that monthly results are inconsistent with the long term mean of the CWeEDS dataset. When using AMY files, the full range of these monthly values are

considered. However, in the case of the single family verified home, the original CWEC was closest to the verified value for total energy consumption annually. Therefore, the CWEC is reliable for whole year energy simulations. This validation is specific to 2018, and it can be said that the original CWEC is most representative of a building with the specific parameters of the modeled home for the year 2018.


To answer the second research questions, simulating 1998 to 2018 AMY years compared to the latest CWEC shows a monthly variability in total energy consumption of 21% for high rise residential building, 20% for low rise buildings, 18% for single family homes and 17% for Energy Star homes. The weather conditions of the updated CWEC represent a broader range of climate conditions than the original CWEC. Annual variability in total energy consumption ranges by only 2%. The single family verified home is run with the updated CWEC file and results found that the 2014 CWEC year is still closest to verified values. For a single family home, the selection of the CWEC can impact heating and cooling load by 4,837 ekWh. In comparison between an Energy Star home and the original single family home, the mean of the years 1998 to 2014 can produce a more favourable EUI, as more savings are achieved with more heating degree days and less cooling degree days. In comparison with a newly created CWEC for years 1998 to 2018, 7 out of 12 typical meteorological months were changed.

8.0 APPENDIX A – MODEL PARAMETERS

Single Family Home Floor Plans – Ground Floor



Second Floor



Basement



Blower door test results

Manual Text Data Entry

Pressurization		Depressurization				
Pre-Test Baseline (Pa)	Building Pressure (Pa)	Fan Config (Up-Down Arrow keys)	Fan Pressure (Pa)	Fan Flow(cfm)		
-0.5	#1 -35	Ring A	25.6	924	<div>Flow Data Source<ul style="list-style-type: none">Fan PressureFlow<div>Fan Blower Door 3 (110V)</div><div>Enter/Edit Temperature and Altitude Data</div><div>Clear Data</div><div>OK</div></div>	
	#2 -40	Ring A	30.7	1010		
	#3 -45	Ring A	36.5	1098		
	#4 -50	Ring A	46.2	1232		
	#5 -55	Ring A	53	1317		
	#6 -60	Ring A	63.9	1443		
	#7 -65	Ring A	72	1530		
	#8 -70	Ring A	78.4	1595		
Post-Test Baseline (Pa)	#9					
-0.5	#10					
	#11					
	#12					

Test Results

Reference Pressure

Airflow at 50 Pascals
1099 cfm50 (+/- 1.2 %)

Leakage Areas
87.1 in² (+/- 8.7 %) Canadian EqLA @ 10 Pa
39.9 in² (+/- 13.6 %) LBL ELA @ 4 Pa

Building Leakage Curve
Flow Coefficient (C) = 45.4 (+/- 21.0 %)
Exponent (n) = 0.814 (+/- 0.053)
Correlation Coefficient = 0.99786

Building Facades: West



South:




East:




North:




Single Family Home Model



High rise residential




Low rise residential



9.0 APPENDIX B – eQUEST REPORTS

Project/Run: 1998 - Baseline Design

Run Date/Time: 12/14/19 @ 12:38




Electric Consumption (kWh)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	2.9	-	14.2	60.2	103.9	115.1	46.0	0.4	-	-	342.5
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	44.8	35.1	33.6	18.0	6.5	15.2	20.2	22.5	10.0	12.2	26.5	35.5	280.2
Pumps & Aux.	18.8	17.6	16.9	13.3	1.5	2.7	-	0.2	1.6	10.0	16.6	18.8	117.8
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	397.9	354.7	387.7	354.8	356.6	401.7	458.4	472.1	381.2	356.9	366.7	388.7	4,677.4

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	17.22	13.68	13.03	7.41	1.74	1.34	0.05	0.07	0.71	5.19	10.63	13.91	84.98
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.78	0.72	0.78	0.78	0.71	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	17.98	14.37	13.78	8.19	2.53	2.06	0.84	0.86	1.43	5.98	11.31	14.66	93.97

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	13.9	66.6	181.2	62.9	49.1	-	-	-	373.8
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	54.1	37.7	37.2	21.6	8.7	13.5	33.2	12.5	11.7	13.9	23.8	41.1	308.9
Pumps & Aux.	18.8	17.4	18.5	14.1	3.4	0.4	-	0.2	1.2	12.0	15.1	18.9	120.0
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	407.3	357.1	390.1	359.3	360.4	404.0	548.7	410.0	385.7	360.2	362.4	394.4	4,739.5

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	20.31	14.51	14.44	8.73	2.76	0.54	0.03	0.08	0.89	5.88	9.53	15.88	93.57
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.78	0.71	0.78	0.78	0.72	0.79	0.68	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	21.06	15.19	15.19	9.51	3.55	1.26	0.82	0.86	1.61	6.66	10.21	16.63	102.56

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	0.1	-	5.5	19.2	40.9	71.8	22.1	1.8	0.3	-	161.5
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	51.2	40.6	30.4	25.8	10.8	6.7	8.4	14.3	8.2	13.8	28.6	52.4	291.0
Pumps & Aux.	18.6	17.6	17.7	16.7	6.7	1.1	-	0.5	4.3	9.1	16.0	19.5	127.7
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	404.1	360.1	382.6	366.1	357.3	350.6	383.7	420.9	358.2	359.0	368.4	406.3	4,517.1

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	19.55	15.70	12.15	10.42	4.19	1.39	0.30	0.27	1.72	5.72	11.37	20.05	102.83
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	20.31	16.38	12.91	11.21	4.97	2.11	1.08	1.06	2.43	6.50	12.06	20.80	111.83

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	11.8	64.2	67.2	160.6	44.2	0.1	-	-	348.0
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	47.8	41.1	39.9	21.7	9.8	14.9	12.6	29.7	11.9	14.5	20.7	36.1	300.7
Pumps & Aux.	18.8	17.6	20.2	14.8	3.8	0.7	0.3	-	2.9	10.9	14.2	18.3	122.4
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	401.0	360.7	394.4	360.1	359.8	403.3	414.4	524.6	382.6	359.9	358.5	388.7	4,707.9

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	18.23	15.83	15.54	8.83	3.41	1.10	0.13	-	1.36	6.09	8.44	14.16	93.11
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.78	0.72	0.78	0.78	0.72	0.79	0.68	0.75	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	18.98	16.51	16.30	9.62	4.20	1.81	0.91	0.78	2.07	6.87	9.12	14.92	102.10

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	59.9	178.4	160.7	84.8	0.8	-	-	484.7
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	40.8	37.7	38.2	24.0	14.6	14.7	32.3	31.1	17.3	16.9	29.5	43.8	341.0
Pumps & Aux.	18.7	17.6	19.3	15.4	11.0	1.1	-	-	0.5	12.7	16.6	19.5	132.3
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	393.9	357.3	392.0	363.0	359.9	399.2	545.1	526.2	426.2	364.8	369.7	397.7	4,894.8

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	15.83	14.64	14.96	9.70	6.11	1.23	-	0.02	0.35	6.91	11.71	16.96	98.42
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.79	0.72	0.78	0.78	0.71	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	16.59	15.32	15.71	10.49	6.90	1.95	0.78	0.81	1.07	7.69	12.39	17.71	107.41

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	0.2	0.2	48.0	68.7	104.2	21.0	2.4	-	-	244.6
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	56.5	49.3	39.4	27.8	13.6	12.1	12.8	20.5	6.5	17.8	27.1	41.5	325.0
Pumps & Aux.	18.8	17.6	18.8	15.2	7.4	0.8	-	-	1.8	14.2	16.8	19.5	130.8
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	409.7	368.9	392.6	366.8	355.5	384.5	415.9	459.0	352.9	368.7	367.4	395.4	4,637.2

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	21.37	18.77	15.36	11.03	5.77	1.52	0.07	0.00	1.14	7.22	10.87	16.18	109.29
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.69	0.76	9.00
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	22.12	19.45	16.11	11.82	6.56	2.23	0.85	0.79	1.85	8.00	11.55	16.94	118.28

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	4.4	32.4	35.5	53.5	55.1	0.2	-	-	181.1
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	59.6	44.6	36.7	25.1	12.2	10.0	7.6	12.3	12.0	14.2	25.4	47.1	306.8
Pumps & Aux.	18.7	17.6	19.0	16.3	6.2	1.1	-	0.2	1.1	10.6	16.5	19.4	126.6
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	412.7	364.2	390.1	365.0	357.1	367.0	377.5	400.3	391.8	359.4	365.5	400.9	4,551.3

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	22.40	17.11	14.46	10.15	4.85	1.43	0.12	0.39	0.58	5.97	10.22	18.10	105.77
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	23.15	17.79	15.22	10.93	5.64	2.15	0.90	1.17	1.30	6.75	10.90	18.85	114.76

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	3.4	117.4	158.6	138.7	75.8	17.1	-	-	511.0
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	55.7	43.6	41.8	22.4	13.3	24.3	30.1	26.4	15.8	18.8	26.8	49.1	368.2
Pumps & Aux.	18.5	17.6	19.5	15.8	8.3	-	-	-	0.9	10.1	14.8	19.5	124.8
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	408.5	363.1	395.7	361.8	359.4	465.3	523.1	499.5	416.0	380.3	365.2	403.0	4,940.8

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	20.92	16.63	16.19	9.06	5.32	0.40	0.00	0.02	0.33	6.13	10.64	18.73	104.38
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.71	0.78	0.78	0.71	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	21.68	17.31	16.95	9.85	6.11	1.12	0.78	0.80	1.05	6.92	11.33	19.49	113.37

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	2.1	5.8	52.4	140.0	115.8	18.7	-	-	-	334.9
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	40.7	43.1	36.2	21.2	10.3	11.4	28.3	22.1	7.3	17.2	25.8	37.4	301.0
Pumps & Aux.	18.8	17.6	18.7	14.2	5.5	0.6	-	-	2.3	13.3	16.5	19.4	126.7
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	393.8	362.7	389.3	361.1	356.0	388.0	502.6	472.2	351.9	364.8	365.8	391.2	4,699.4

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	15.72	16.48	14.18	8.48	3.93	0.72	0.02	0.06	1.68	7.15	10.33	14.60	93.35
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.69	0.75	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	16.48	17.16	14.93	9.27	4.72	1.43	0.80	0.84	2.40	7.94	11.02	15.36	102.34

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	0.6	12.1	86.8	78.8	145.3	74.2	9.3	-	-	407.3
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	48.0	51.5	39.2	28.3	10.8	17.2	15.2	26.1	15.5	10.6	29.0	47.5	338.8
Pumps & Aux.	18.5	17.6	18.9	15.0	5.7	0.6	-	-	1.1	5.4	17.4	19.5	119.5
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	400.8	371.0	392.4	367.4	363.0	428.1	428.4	505.8	414.4	359.7	370.0	401.4	4,802.4

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	18.29	19.37	15.22	11.17	3.55	0.44	0.13	0.10	0.67	3.64	11.48	18.18	102.24
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.71	0.78	0.78	0.71	0.78	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	19.04	20.05	15.98	11.96	4.33	1.16	0.91	0.88	1.38	4.43	12.17	18.93	111.23

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	0.6	12.1	86.8	78.8	145.3	74.2	9.3	-	-	407.3
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	48.0	51.5	39.2	28.3	10.8	17.2	15.2	26.1	15.5	10.6	29.0	47.5	338.8
Pumps & Aux.	18.5	17.6	18.9	15.0	5.7	0.6	-	-	1.1	5.4	17.4	19.5	119.5
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	400.8	371.0	392.4	367.4	363.0	428.1	428.4	505.8	414.4	359.7	370.0	401.4	4,802.4

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	18.29	19.37	15.22	11.17	3.55	0.44	0.13	0.10	0.67	3.64	11.48	18.18	102.24
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.71	0.78	0.78	0.71	0.78	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	19.04	20.05	15.98	11.96	4.33	1.16	0.91	0.88	1.38	4.43	12.17	18.93	111.23

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	0.4	25.8	28.8	93.4	29.9	-	-	-	178.3
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	58.0	41.9	36.3	24.2	9.4	8.9	6.0	19.6	8.6	18.7	23.0	46.1	300.7
Pumps & Aux.	18.8	17.6	19.6	15.5	5.0	1.2	0.1	-	2.0	12.4	17.0	19.5	128.6
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	411.2	361.5	390.2	363.2	349.2	359.4	369.2	447.4	364.1	365.5	363.5	400.0	4,544.4

Gas Consumption (Btu x1000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	21.89	16.14	14.30	9.84	4.06	1.74	0.38	0.18	1.14	7.77	9.32	17.81	104.57
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.68	0.76	9.00
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	22.65	16.82	15.06	10.63	4.85	2.46	1.17	0.96	1.85	8.56	10.00	18.56	113.56

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	3.6	1.6	48.1	70.2	71.7	27.2	4.9	-	-	227.3
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	46.4	46.4	41.4	19.1	13.9	11.7	14.0	15.1	7.7	17.9	29.5	47.6	310.6
Pumps & Aux.	17.7	17.6	19.9	12.1	10.0	0.3	-	-	1.2	12.7	16.6	19.3	127.3
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	398.4	365.9	395.7	358.4	359.8	383.5	418.6	421.1	359.8	369.9	369.7	401.3	4,602.1

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	17.85	17.77	16.21	7.63	5.79	0.99	0.08	0.21	1.09	7.11	11.77	18.37	104.86
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	18.61	18.45	16.97	8.42	6.57	1.70	0.86	1.00	1.80	7.89	12.45	19.13	113.85

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	0.1	30.4	38.9	155.1	140.3	35.9	-	-	-	400.7
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	52.3	44.6	29.5	16.1	14.4	8.6	31.5	27.8	10.3	13.6	25.0	48.8	322.3
Pumps & Aux.	18.8	17.6	17.6	10.7	5.7	-	-	-	1.5	11.6	17.4	19.5	120.3
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	405.5	364.2	381.4	350.5	384.9	371.0	520.9	502.4	371.3	359.5	365.9	402.7	4,780.1

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	19.75	17.02	11.67	6.69	3.51	0.57	0.09	0.07	1.44	5.73	9.96	18.63	95.14
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.78	0.78	0.72	0.78	0.78	0.72	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	20.51	17.71	12.42	7.48	4.29	1.29	0.87	0.85	2.16	6.52	10.64	19.39	104.13

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	1.0	48.3	183.6	104.4	27.9	5.0	-	-	370.2
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	55.2	46.6	40.3	27.0	10.5	10.3	34.3	20.5	7.3	15.7	21.0	39.1	327.8
Pumps & Aux.	18.8	17.6	19.4	17.2	4.9	0.1	-	-	1.6	11.6	12.9	19.1	123.3
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	408.4	366.1	394.1	367.7	350.8	382.2	552.3	459.3	360.4	366.6	357.5	392.6	4,758.1

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	20.74	17.65	15.63	10.78	4.46	0.58	0.02	0.01	0.85	6.14	8.54	15.19	100.58
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.68	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	21.49	18.33	16.38	11.57	5.24	1.29	0.80	0.80	1.56	6.92	9.22	15.95	109.57

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	0.4	-	24.5	97.4	164.3	128.0	38.0	-	-	-	452.6
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	45.2	37.0	24.7	22.3	10.1	19.6	31.1	24.4	10.6	15.2	27.7	39.1	307.0
Pumps & Aux.	18.8	17.6	14.8	15.6	2.7	0.2	-	-	2.7	12.2	17.7	19.4	121.6
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	398.4	356.6	374.2	361.5	371.6	440.8	529.8	486.8	374.9	361.7	369.0	392.8	4,818.1

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	17.29	14.32	9.89	9.02	2.33	0.66	-	0.02	1.48	6.37	11.00	15.17	87.55
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.75	0.79	0.78	0.71	0.78	0.78	0.72	0.79	0.69	0.76	8.98
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	18.04	15.01	10.65	9.80	3.12	1.37	0.78	0.81	2.19	7.15	11.69	15.93	96.54

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	12.3	49.9	50.7	74.8	48.6	-	-	-	236.3
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	59.1	50.9	46.2	25.6	12.2	10.9	11.0	16.1	12.7	13.7	32.6	42.2	333.1
Pumps & Aux.	18.8	17.6	20.1	15.8	4.6	-	-	-	2.2	9.7	16.1	19.5	124.5
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	412.3	370.4	400.6	365.0	363.5	384.4	396.0	425.3	387.2	357.7	372.3	396.0	4,630.7

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	22.30	19.36	17.89	10.33	4.42	0.42	0.27	0.20	1.50	5.88	12.87	16.47	111.92
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.69	0.76	9.00
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	23.05	20.04	18.65	11.12	5.21	1.13	1.05	0.98	2.22	6.67	13.56	17.23	120.92

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	16.7	25.5	152.2	113.9	99.4	7.5	1.1	-	416.3
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	53.9	56.4	39.8	23.4	9.7	6.8	29.7	23.0	20.5	14.2	20.1	33.6	331.0
Pumps & Aux.	18.8	17.6	20.1	14.7	4.6	0.2	-	-	0.3	10.2	13.6	17.8	117.8
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	407.1	375.9	394.3	361.7	365.4	356.0	516.2	471.3	443.6	366.2	358.3	385.7	4,801.9

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	20.23	20.97	15.40	9.40	2.59	0.70	0.12	0.08	0.26	5.44	8.04	13.20	96.44
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.78	0.72	0.78	0.78	0.71	0.79	0.68	0.75	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	20.99	21.66	16.15	10.19	3.38	1.42	0.90	0.87	0.98	6.22	8.72	13.95	105.44

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	17.0	97.2	184.9	237.2	105.7	22.2	-	-	664.2
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	46.2	38.9	33.4	25.0	11.1	16.3	34.6	44.8	20.0	14.5	20.0	43.4	348.2
Pumps & Aux.	18.8	17.0	18.6	16.0	5.8	0.3	-	-	0.6	8.0	14.1	19.5	118.6
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	399.3	357.8	386.3	364.6	368.3	437.4	553.8	616.3	449.9	379.1	357.7	397.3	5,067.8

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	17.61	14.94	13.14	9.98	3.48	0.19	0.01	-	0.35	4.27	8.10	16.73	88.81
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.79	0.71	0.78	0.78	0.71	0.78	0.68	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	18.37	15.62	13.90	10.76	4.27	0.90	0.80	0.78	1.07	5.06	8.79	17.49	97.80

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	0.5	8.8	43.3	76.8	89.6	95.8	15.3	-	-	330.1
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	44.9	35.7	38.4	18.8	14.1	9.6	15.2	18.7	20.2	10.4	26.5	48.3	300.8
Pumps & Aux.	18.8	17.1	19.5	12.8	7.7	0.3	-	-	1.6	6.0	16.9	19.5	120.2
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	398.1	354.8	392.3	355.6	365.0	376.7	426.3	442.7	441.1	366.0	367.0	402.2	4,687.9

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	17.29	13.91	15.02	7.71	5.24	0.66	0.01	0.09	0.54	3.37	10.63	18.49	92.96
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.79	0.72	0.78	0.78	0.71	0.78	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	18.05	14.59	15.78	8.50	6.02	1.38	0.79	0.88	1.25	4.16	11.32	19.24	101.95

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	21.6	76.2	162.5	162.3	95.4	-	-	-	517.9
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	49.7	38.5	36.4	31.9	8.4	15.9	30.4	32.7	20.4	17.4	32.4	41.6	355.7
Pumps & Aux.	18.8	17.0	20.2	17.3	2.6	0.1	-	-	0.9	12.6	18.1	19.1	126.6
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	402.8	357.6	391.0	372.8	367.0	415.7	527.2	529.3	440.2	364.4	374.0	395.1	4,937.1

Gas Consumption (Btu x000,000)


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	18.86	14.88	14.28	12.59	2.12	0.67	-	-	0.76	7.21	12.76	16.15	100.26
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.78	0.72	0.78	0.78	0.71	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	19.62	15.56	15.04	13.38	2.90	1.38	0.78	0.78	1.47	7.99	13.44	16.90	109.25

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	5.3	63.0	121.0	92.4	22.4	-	0.2	-	304.2
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	53.7	43.8	36.3	23.4	10.6	14.4	24.5	18.0	6.6	14.0	28.6	41.1	315.1
Pumps & Aux.	18.8	17.6	18.8	15.5	5.5	0.7	-	-	1.8	11.6	16.0	19.5	125.6
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	406.9	363.4	389.4	362.5	355.7	401.6	479.8	444.8	354.4	360.0	368.3	395.0	4,681.8

Gas Consumption (Btu x000,000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	20.30	16.79	14.24	9.53	4.09	0.98	0.06	0.02	1.06	5.90	11.32	15.98	100.29
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.68	0.76	0.79	0.79	0.72	0.78	0.78	0.72	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	21.06	17.48	15.00	10.32	4.88	1.69	0.85	0.80	1.78	6.69	12.01	16.74	109.29

**Electric Consumption (kWh)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	10.5	28.5	118.6	111.4	44.8	-	0.1	-	313.9
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	47.2	43.6	35.8	23.0	9.8	6.8	24.0	21.9	9.8	13.2	28.5	46.4	309.9
Pumps & Aux.	18.5	17.6	18.8	15.5	3.8	-	-	0.2	1.6	9.7	16.0	19.4	120.9
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	218.8	197.6	218.8	211.7	218.8	211.7	218.8	218.8	211.7	218.8	211.7	218.8	2,576.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	115.6	104.4	115.6	111.9	115.6	111.9	115.6	115.6	111.9	115.6	111.9	115.6	1,360.9
Total	400.0	363.1	388.9	362.0	358.5	358.9	476.9	467.8	379.8	357.2	368.2	400.2	4,681.5

Gas Consumption (Btu x000,000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	18.09	16.75	14.08	9.39	3.53	0.68	0.10	0.09	0.73	5.67	11.33	17.87	98.30
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.76	0.69	0.76	0.79	0.78	0.72	0.78	0.78	0.72	0.79	0.69	0.76	8.99
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	18.85	17.43	14.84	10.17	4.31	1.39	0.88	0.88	1.45	6.45	12.01	18.63	107.29

10.0 REFERENCES

- [1] A. P. Aaron-Morrison *et al.*, “State of the climate in 2016,” *Bull. Am. Meteorol. Soc.*, vol. 98, no. 8, p. Si-S280, 2017.
- [2] Environment and Climate Change Canada, “Canada Weather Stats,” *weatherstats.ca*, 2019.
[Online]. Available: <https://www.weatherstats.ca/>. [Accessed: 01-Oct-2019].
- [3] L. King *et al.*, “The City of Toronto ZERO EMISSIONS BUILDINGS FRAMEWORK 2 Prepared for the City Planning Division, City of Toronto by Client Representatives,” pp. 1–118, 2017.
- [4] KPMG, “End-to-End Review of the Development Review Process,” 2019.
- [5] “Development Applications.” [Online]. Available:
<http://app.toronto.ca/DevelopmentApplications/mapSearchSetup.do?action=init>. [Accessed: 14-Dec-2019].
- [6] L. Yang, J. C. Lam, J. Liu, and C. L. Tsang, “Building energy simulation using multi-years and typical meteorological years in different climates,” *Energy Convers. Manag.*, vol. 49, no. 1, pp. 113–124, Jan. 2008.
- [7] R. Morris, “Final Report-Updating CWEEDS Weather Files,” 2016.
- [8] Environment Canada, “Engineering Climate Datasets,” *Engineering Climate Services Unit*, 2019.
[Online]. Available: https://climate.weather.gc.ca/prods_servs/engineering_e.html. [Accessed: 28-Sep-2019].
- [9] A. L. S. Chan, “Generation of typical meteorological years using genetic algorithm for different energy systems,” *Renew. Energy*, vol. 90, pp. 1–13, 2016.
- [10] W. M. and K. Urban, “User’s Manual For TMY2s - typical meteorological year (TMY) data,” 1994.

- [11] I. A. Rahman and J. Dewsbury, "Selection of typical weather data (test reference years) for Subang, Malaysia," *Build. Environ.*, vol. 42, no. 10, pp. 3636–3641, Oct. 2007.
- [12] H. Yang and L. Lu, "Study of typical meteorological years and their effect on building energy and renewable energy simulations," *ASHRAE Trans.*, pp. 424–431, 2004.
- [13] Y. Jiang, "Generation of typical meteorological year for different climates of China," *Energy*, vol. 35, no. 5, pp. 1946–1953, May 2010.
- [14] J. J. Hirsch, "eQuest Quick energy simulation tool," *Www.Doe2.Com/Equest*. 2014.
- [15] H. Yassaghi and S. Hoque, "An overview of climate change and building energy: Performance, responses and uncertainties," *Buildings*, vol. 9, no. 7, 2019.
- [16] J. J. Hirsch, "DOE22 Volume 2 Dictionary," *Program*, vol. 2, no. February, 2009.
- [17] NCDC, "Solar and Meteorological Surface Observation Network, 1961-1990, Version 1.0." National Climatic Data Center, U.S. Department of Commerce, Asheville, 1993.
- [18] D. B. Crawley, "Which weather data should you use for energy simulations of commercial buildings?," *ASHRAE Trans.*, vol. 104, no. 2, pp. 498–515, 1998.
- [19] M. F. Jentsch, C. K. Chang, J. P. A. B, and A. R. Bahaj, "No Title," in *Development of climate change adapted weather files for building performance simulation: implications for Southeast Asia*, 2009.
- [20] M. Hosseini, F. Tardy, and B. Lee, "Cooling and heating energy performance of a building with a variety of roof designs; the effects of future weather data in a cold climate," *J. Build. Eng.*, vol. 17, no. October 2017, pp. 107–114, 2018.
- [21] D. Crawley, "Estimating the impacts of climate change and urbanization on building performance," *J. Build. Perform. Simul.*, vol. 1, no. 918153077, pp. 91–115, 2008.

- [22] D. B. Crawley, L. K. Lawrie, and B. Systems, "Should We Be Using Just ' Typical ' Weather Data in Building Performance Simulation ? S hould We Be Using Just ' Typical ' Weather Data in Building Performance Simulation ? DHL Consulting LLC , Pagosa Springs , CO , USA," no. September, 2019.
- [23] S. Abdelmutaal, F. F. Chen, D. Ph, H. Sharif, and D. Ph, "A Method to Generate Input Data for Urban Scale Building Energy Models," The University of Texas at San Antonio, 2019.
- [24] I. A. Al-Mofeez, M. Y. Numan, K. A. Alshaibani, and F. A. Al-Maziad, "Review of typical vs. synthesized energy modeling weather files," in *Journal of Renewable and Sustainable Energy*, 2012, vol. 4, no. 1.
- [25] A. Gonzalez Caceres, D. G. Zenginis, and T. A. Vik, "The impact of the weather data file on the energy performance certificate, the case of Norway," in *Proceedings of The 59th Conference on imulation and Modelling (SIMS 59), 26-28 September 2018, Oslo Metropolitan University, Norway*, 2018, vol. 153, pp. 342–349.
- [26] M. F. Jentsch, C. K. Chang, J. P. A. B, A. R. Bahaj, and Y. H. Yau, "Development of Climate Change Adapted Weather Files for Building Performance Simulation: Implications for Southeast Asia," in *3rd International Conference on Sustainable Energy and Environment (SEE 2009)*, 2009.
- [27] Y. J. Huang, "Using Satellite-Derived Solar Radiation to Create Weather Files of Unprecedented Accuracy and Reliability White Box Technologies , Inc ., Moraga CA USA Abstract Public Sources of Weather Station Data Public Sources of Satellite-Derived Solar Radiation Dat."
- [28] info and huksefluxcom, "Hukseflux Thermal Sensors."
- [29] B. Marion, "A model for deriving the direct normal and diffuse horizontal irradiance from the global tilted irradiance," *Sol. Energy*, vol. 122, pp. 1037–1046, Dec. 2015.
- [30] C. B. Baker, "Evaluation of the estimation of diffuse irradiance from global and direct normal

- irradiance measurements,” *Sol. Energy*, vol. 32, no. 1, pp. 25–31, 1984.
- [31] M. Lave, W. Hayes, A. Pohl, and C. W. Hansen, “Evaluation of global horizontal irradiance to plane-of-array irradiance models at locations across the United States,” *IEEE J. Photovoltaics*, vol. 5, no. 2, pp. 597–606, Mar. 2015.
- [32] R. Djebbar, R. Morris, D. Thevenard, R. Perez, and J. Schlemmer, “Assessment of SUNY Version 3 Global Horizontal and Direct Normal Solar Irradiance in Canada,” *Energy Procedia*, vol. 30, pp. 1274–1283, Jan. 2012.
- [33] R. Djebbar, R. Morris, D. Thevenard, R. Perez, and J. Schlemmer, “Assessment of SUNY version 3 global horizontal and direct normal solar irradiance in Canada,” *Energy Procedia*, vol. 30, pp. 1274–1283, 2012.
- [34] M. Sengupta, Y. Xie, A. Lopez, A. Habte, G. Maclaurin, and J. Shelby, “The National Solar Radiation Data Base (NSRDB),” *Renew. Sustain. Energy Rev.*, vol. 89, no. September 2017, pp. 51–60, 2018.
- [35] M. F. Jentsch, A. B. S. Bahaj, and P. A. B. James, “Climate change future proofing of buildings- Generation and assessment of building simulation weather files,” *Energy Build.*, vol. 40, no. 12, pp. 2148–2168, 2008.
- [36] “WRF Model Users Site.” [Online]. Available: <https://www2.mmm.ucar.edu/wrf/users/>. [Accessed: 23-Dec-2019].
- [37] J. Bravo Dias, G. Carrilho da Graça, and P. M. M. Soares, “Comparison of methodologies for generation of future weather data for building thermal energy simulation,” *Energy Build.*, vol. 206, Jan. 2020.
- [38] Toronto Environment Office, “Toronto’s Future Weather and Climate Driver Study: Outcomes Report,” vol. 2049, p. 15, 2012.

- [39] R. Evins, "Multi-level optimization of building design, energy system sizing and operation," *Energy*, vol. 90, pp. 1775–1789, 2015.
- [40] C. Sousa, A. Pina, C. Cerezo, and C. Reinhart, "The use of multi-detail building archetypes in urban energy modelling," *Energy Procedia*, vol. 111, no. September 2016, pp. 817–825, 2017.
- [41] National Research Council Canada, *National Energy Code of Canada for Buildings 2017*. 2017, pp. 1–335.
- [42] ASHRAE, "Ventilation for Acceptable Indoor Air Quality," 2019.
- [43] A. Chief Planner, E. Director, and C. Planning, "REPORT FOR ACTION Toronto Green Standard Review and Update," 2017.
- [44] C. Nrcc, M. National, E. Code, and B. Division, "Building code act, 1992," vol. 29, no. 1, 2012.
- [45] "Energy/GHG & Resilience for Mid to High-Rise Residential & all Non-Residential Development – City of Toronto." [Online]. Available: <https://www.toronto.ca/city-government/planning-development/official-plan-guidelines/toronto-green-standard/toronto-green-standard-version-3/mid-to-high-rise-residential-all-non-residential-version-3/energy-ghg-resilience-for-mid-to-high-rise-residential-all-non-residential-development/>. [Accessed: 17-Dec-2019].
- [46] Natural Resources Canada, "ENERGY STAR® for New Homes Standard - Version 12.7," pp. 1–80, 2016.
- [47] Housing Assistance Council, "Building Affordable ENERGY STAR ®," 2009.
- [48] G. R. Ruiz and C. F. Bandera, "Validation of calibrated energy models: Common errors," *Energies*, vol. 10, no. 10, 2017.
- [49] American Society of Heating Ventilation and Air Conditioning Engineers (ASHRAE), "Guideline 14-

- 2002,” Atlanta, 2002.
- [50] American Society of Heating Ventilation and Air Conditioning Engineers (ASHRAE), “Guideline 14-2014,” Atlanta, 2014.
- [51] L. Webster and J. Bradford, “M&V Guidelines: Measurement and Verification for Federal Energy Projects,” Washington, 2008.
- [52] L. Webster *et al.*, “M&V Guidelines: Measurement and Verification for Federal Energy Projects,” Washington, 2015.
- [53] Efficiency Valuation Organization, “International Performance Measurement and Verification Protocol: Concepts and Options for Determining Energy and Water Savings, Volume I,” Washington, 2012.
- [54] K. Madison, “Large Batch DOE-2 Modeling with eQUEST,” 2012. [Online]. Available: <http://groupspaces.com/IBPSASeattle/pages/past-presentations>. [Accessed: 01-Jan-2019].
- [55] Environment Canada, “Daily Data Report,” 2003. [Online]. Available: https://climat.meteo.gc.ca/climate_data/daily_data_e.html?hlyRange=1953-01-01%7C2013-06-13&dlyRange=1937-11-01%7C2013-06-13&mlyRange=1937-01-01%7C2013-06-01&StationID=5097&Prov=ON&urlExtension=_e.html&searchType=stnName&optLimit=yearRange&StartYear=1840&E. [Accessed: 30-Nov-2019].
- [56] J. Ferdyn-Grygierek, D. Bartosz, A. Specjał, and K. Grygierek, “Analysis of accuracy determination of the seasonal heat demand in buildings based on short measurement periods,” *Energies*, vol. 11, no. 10, 2018.
- [57] A. Selvacanabady and K. Judd, “The Influence of Occupancy on Building Energy Use Intensity and the Utility of an Occupancy-Adjusted Performance Metric (PNNL-26019),” p. 40, 2017.